

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Oct-22

System Name:	Johnson Creek Water Service		ID#: 41 01072				WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3	0.05	0.05	0.23	OFF	OFF	OFF	0.23	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	0.03	0.03	0.03	
7	0.23	OFF	OFF	OFF	0.04	0.03	0.23	
8	0.14	OFF	OFF	OFF	OFF	OFF	0.14	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	0.03	0.04	0.04	
11	0.20	OFF	OFF	OFF	OFF	OFF	0.20	
12	OFF	OFF	OFF	OFF	OFF	0.04	0.04	
13	0.04	OFF	OFF	OFF	OFF	0.03	0.04	
14	0.03	OFF	OFF	OFF	OFF	OFF	0.03	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	0.08	0.08	
17	0.04	0.04	OFF	0.08	0.08	OFF	0.08	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	0.04	0.04	0.04	
22	0.04	OFF	OFF	OFF	OFF	OFF	0.04	
23	OFF	OFF	OFF	OFF	0.08	0.03	0.08	
24	0.03	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	0.02	0.02	0.02	
26	0.02	OFF	OFF	OFF	0.04	0.03	0.04	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	OFF	OFF	0.04	0.04	
30	0.04	0.04	OFF	OFF	0.03	0.03	0.04	
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:	PRINTED NAME: Aaron Olson
	SIGNATURE:  DATE: 11-9-22
	PHONE #: (503) 487-7591 CERT #: T-09128

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name: Johnson Creek Water Service	ID#: 41 01072	Month/Year: Oct-22	Disinfection Giardia Log Inactive:		1		

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Oct	OFF	128						
2-Oct	0.8	128	102.4	13.0	7.7	39.4	Yes	80
3-Oct	OFF	128						
4-Oct	OFF	128						
5-Oct	OFF	128						
6-Oct	0.3	128	38.4	15.0	7.6	31.4	Yes	80
7-Oct	0.5	128	64.0	15.0	7.6	32.1	Yes	80
8-Oct	0.5	128	64.0	15.0	7.7	33.4	Yes	80
9-Oct	OFF	128						
10-Oct	0.4	128	51.2	15.0	7.6	31.8	Yes	80
11-Oct	OFF	128						
12-Oct	0.5	128	64.0	14.0	7.6	34.4	Yes	80
13-Oct	0.6	128	76.8	14.0	7.7	36.1	Yes	80
14-Oct	OFF	128						
15-Oct	OFF	128						
16-Oct	0.4	128	51.2	15.0	7.4	29.5	Yes	80
17-Oct	0.8	128	102.4	14.0	7.4	33.0	Yes	80
18-Oct	OFF	128						
19-Oct	OFF	128						
20-Oct	OFF	128						
21-Oct	0.5	128	64.0	15.0	7.6	32.1	Yes	80
22-Oct	0.7	128	89.6	14.0	7.7	36.5	Yes	80
23-Oct	0.6	128	76.8	14.0	7.7	36.1	Yes	80
24-Oct	0.8	128	102.4	14.0	7.7	36.9	Yes	80
25-Oct	0.8	128	102.4	13.0	7.6	38.0	Yes	80
26-Oct	0.8	128	102.4	12.0	7.7	42.3	Yes	80
27-Oct	0.6	128	76.8	13.0	7.5	35.8	Yes	80
28-Oct	OFF	128						
29-Oct	0.7	128	89.6	13.0	7.4	34.9	Yes	80
30-Oct	0.8	128	102.4	13.0	7.5	36.6	Yes	80
31-Oct	OFF	128						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018