

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Sep-23

System Name: Johnson Creek Water Service ID#: 41 01072 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	0.03	0.03	0.03
3	0.01	0.01	OFF	0.03	OFF	OFF	0.03
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	0.04	0.04	0.04
6	0.04	0.04	OFF	OFF	OFF	0.03	0.04
7	OFF	OFF	OFF	OFF	OFF	0.08	0.08
8	0.04	OFF	OFF	OFF	OFF	OFF	0.04
9	OFF	OFF	OFF	OFF	0.10	OFF	0.10
10	0.03	0.03	OFF	OFF	OFF	OFF	0.03
11	OFF	OFF	OFF	0.04	0.04	0.04	0.04
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	0.05	OFF	0.05
15	OFF	OFF	OFF	OFF	0.23	OFF	0.23
16	OFF	OFF	OFF	OFF	OFF	0.03	0.03
17	0.18	OFF	OFF	0.03	OFF	0.30	0.30
18	OFF	OFF	OFF	0.04	0.03	OFF	0.04
19	OFF	OFF	OFF	0.04	0.03	OFF	0.04
20	0.03	0.15	OFF	OFF	OFF	OFF	0.15
21	OFF	OFF	OFF	OFF	OFF	0.09	0.09
22	OFF	OFF	OFF	0.05	OFF	0.09	0.09
23	0.09	0.08	OFF	OFF	OFF	OFF	0.09
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	0.20	0.04	OFF	0.20
26	0.04	0.04	OFF	OFF	0.03	0.04	0.04
27	0.05	OFF	OFF	OFF	OFF	OFF	0.05
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	0.03	0.03	0.03
30	0.03	OFF	OFF	OFF	OFF	OFF	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:	PRINTED NAME: Jeffrey Olson
	SIGNATURE: <i>Jeffrey Olson</i> DATE: 10-06-23
	PHONE #: (503)-554-8333 CERT #: T766039

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name:	Johnson Creek Water Service	ID#: 41 01072	Month/Year:	Sep-23	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Sep	OFF							
2-Sep	0.60	128	77.0	17.0	7.7	29.5	Yes	80
3-Sep	0.80	128	102.0	16.0	7.6	31.1	Yes	80
4-Sep	OFF							
5-Sep	0.70	128	90.0	15.0	7.8	35.4	Yes	80
6-Sep	0.60	128	77.0	16.0	7.7	31.6	Yes	80
7-Sep	0.50	128	64.0	16.0	7.8	32.4	Yes	80
8-Sep	0.50	128	64.0	16.0	7.9	33.4	Yes	80
9-Sep	0.60	128	77.0	15.0	7.6	32.5	Yes	80
10-Sep	0.70	128	90.0	14.0	7.5	33.9	Yes	80
11-Sep	0.80	128	102.0	16.0	7.5	30.0	Yes	80
12-Sep	OFF							
13-Sep	OFF							
14-Sep	0.60	128	77.0	16.0	7.4	28.2	Yes	80
15-Sep	0.50	128	64.0	16.0	7.5	29.0	Yes	80
16-Sep	0.40	128	51.0	16.0	7.6	29.7	Yes	80
17-Sep	0.70	128	90.0	16.0	7.6	30.8	Yes	80
18-Sep	0.70	128	90.0	15.0	7.6	32.9	Yes	80
19-Sep	0.90	128	115.0	15.0	7.5	32.4	Yes	80
20-Sep	0.90	128	115.0	14.0	7.5	34.6	Yes	80
21-Sep	0.80	128	1.0	15.0	7.4	30.9	No	80
22-Sep	0.80	128	102.0	14.0	7.5	34.3	Yes	80
23-Sep	0.80	128	102.0	15.0	7.4	30.9	Yes	80
24-Sep	OFF							
25-Sep	0.70	128	90.0	15.0	7.5	31.7	Yes	80
26-Sep	0.60	128	77.0	15.0	7.4	30.2	Yes	80
27-Sep	0.60	128	77.0	15.0	7.5	31.3	Yes	80
28-Sep	OFF							
29-Sep	0.40	128	51.0	16.0	7.5	28.6	Yes	80
30-Sep	0.40	128	51.0	15.0	7.6	31.8	Yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350