

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Feb-25

System Name: Johnson Creek Water Service		ID#: 41 01072					WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3-Feb	OFF	OFF	OFF	OFF	OFF	0.010	0.010	
4-Feb	0.010	OFF	OFF	OFF	OFF	0.030	0.030	
5-Feb	0.010	OFF	0.010	OFF	OFF	0.010	0.010	
6-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10-Feb	OFF	OFF	OFF	0.040	0.010	0.080	0.080	
11-Feb	OFF	OFF	OFF	OFF	OFF	0.030	0.030	
12-Feb	0.010	0.010	OFF	0.09	OFF	OFF	0.090	
13-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15-Feb	OFF	OFF	OFF	0.01	0.010	OFF	0.010	
16-Feb	OFF	OFF	OFF	0.010	0.010	OFF	0.010	
17-Feb	OFF	OFF	OFF	OFF	0.040	OFF	0.040	
18-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19-Feb	OFF	OFF	OFF	OFF	0.060	0.040	0.060	
20-Feb	OFF	OFF	OFF	OFF	0.010	0.010	0.010	
21-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25-Feb	OFF	OFF	OFF	0.020	0.010	0.010	0.020	
26-Feb	0.100	OFF	OFF	OFF	0.010	0.010	0.100	
27-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28-Feb	OFF	OFF	OFF	OFF	OFF	OFF	OFF	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Jeffrey Olson	
	SIGNATURE: <i>Jeffrey Olson</i>	3/7/2025
	PHONE #: (503)-554-8333	CERT #: T766039

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name: Johnson Creek Water Service	ID#: 41 01072	Month/Year: Feb-25	Disinfection Giardia Log Inactive:		1		

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Feb	OFF							
2-Feb	OFF							
3-Feb	0.40	300	120.0	8.0	7.5	49.0	Yes	80
4-Feb	0.50	300	150.0	9.0	7.4	44.8	Yes	80
5-Feb	0.40	300	120.0	8.0	7.4	47.3	Yes	80
6-Feb	OFF							
7-Feb	OFF							
8-Feb	OFF							
9-Feb	OFF							
10-Feb	0.40	300	120.0	7.0	7.5	52.4	Yes	80
11-Feb	0.40	300	120.0	8.0	7.5	49.0	Yes	80
12-Feb	0.50	300	150.0	8.0	7.7	53.3	Yes	80
13-Feb	OFF							
14-Feb	OFF							
15-Feb	0.50	300	150.0	8.0	7.6	51.4	Yes	80
16-Feb	0.50	300	150.0	8.0	7.9	57.2	Yes	80
17-Feb	0.50	300	150.0	8.0	8.2	63.8	Yes	80
18-Feb	OFF							
19-Feb	0.40	300	120.0	8.0	7.9	56.6	Yes	80
20-Feb	0.50	300	150.0	9.0	7.7	49.8	Yes	80
21-Feb	OFF							
22-Feb	OFF							
23-Feb	OFF							
24-Feb	OFF							
25-Feb	0.40	300	120.0	10.0	7.7	46.1	Yes	80
26-Feb	0.40	300	120.0	10.0	7.8	47.7	Yes	80
27-Feb	OFF							
28-Feb	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350