

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Apr-25

System Name: Johnson Creek Water Service		ID#: 41 01072		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Apr	OFF	OFF	OFF	OFF	OFF	0.080	0.080
2-Apr	OFF	OFF	OFF	OFF	OFF	0.010	0.010
3-Apr	0.010	OFF	OFF	OFF	OFF	OFF	0.010
4-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5-Apr	OFF	OFF	OFF	OFF	0.010	0.030	0.030
6-Apr	0.010	OFF	OFF	OFF	OFF	OFF	0.010
7-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8-Apr	OFF	OFF	OFF	OFF	OFF	0.010	0.010
9-Apr	0.010	OFF	OFF	OFF	OFF	0.100	0.100
10-Apr	0.030	0.03	OFF	OFF	OFF	OFF	0.030
11-Apr	OFF	OFF	OFF	OFF	OFF	0.030	0.030
12-Apr	0.030	OFF	OFF	OFF	OFF	OFF	0.030
13-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14-Apr	OFF	OFF	OFF	OFF	OFF	0.010	0.010
15-Apr	0.030	OFF	OFF	OFF	OFF	OFF	0.030
16-Apr	OFF	OFF	OFF	OFF	0.040	0.010	0.040
17-Apr	0.010	0.01	OFF	0.02	OFF	OFF	0.020
18-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20-Apr	OFF	OFF	OFF	OFF	0.050	OFF	0.050
21-Apr	OFF	OFF	OFF	OFF	OFF	0.010	0.010
22-Apr	0.035	0.03	0.03	0.03	0.100	0.040	0.100
23-Apr	0.030	0.030	OFF	0.050	OFF	OFF	0.050
24-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26-Apr	OFF	OFF	OFF	0.040	0.030	0.030	0.040
27-Apr	0.030	0.03	0.04	OFF	OFF	OFF	0.040
28-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29-Apr	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30-Apr	OFF	OFF	OFF	OFF	0.050	0.010	0.050

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		

Notes:	PRINTED NAME: Curtis Olson	
	SIGNATURE: <i>Curtis Olson</i>	5/7/2025
	PHONE #: (503)-554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A		Inactivation
System Name: Johnson Creek Water Service		ID#: 41 01072		Month/Year: Apr-25		Disinfection <i>Giardia</i> Log Inactive:		1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Apr	0.60	300	150.0	12.0	7.7	41.3	Yes	80
2-Apr	0.50	300	150.0	10.0	7.6	45.0	Yes	80
3-Apr	0.50	300	150.0	11.0	7.7	43.6	Yes	80
4-Apr	OFF							
5-Apr	0.50	300	120.0	12.0	7.7	40.9	Yes	80
6-Apr	0.50	300	120.0	12.0	7.6	39.5	Yes	80
7-Apr	OFF							
8-Apr	0.40	300	120.0	11.0	7.7	43.1	Yes	80
9-Apr	0.40	300	120.0	12.0	7.7	40.4	Yes	80
10-Apr	0.40	300	150.0	11.0	7.7	43.1	Yes	80
11-Apr	0.50	300	150.0	11.0	7.7	43.6	Yes	80
12-Apr	0.40	300	210.0	11.0	7.7	43.1	Yes	80
13-Apr	OFF							
14-Apr	0.50	300	210.0	11.0	7.7	43.6	Yes	80
15-Apr	0.50	300	210.0	11.0	7.7	43.6	Yes	80
16-Apr	0.50	300	210.0	11.0	7.4	39.3	Yes	80
17-Apr	0.50	300	150.0	12.0	7.4	36.8	Yes	80
18-Apr	OFF							
19-Apr	OFF							
20-Apr	0.50	300	150.0	12.0	7.4	36.8	Yes	80
21-Apr	0.50	300	150.0	12.0	7.5	38.1	Yes	80
22-Apr	0.50	300	150.0	12.0	7.4	36.8	Yes	80
23-Apr	0.70	300	150.0	12.0	7.4	37.6	Yes	80
24-Apr	OFF							
25-Apr	OFF							
26-Apr	0.70	300	150.0	12.0	7.3	36.4	Yes	80
27-Apr	0.80	300	150.0	11.0	7.3	39.2	Yes	80
28-Apr	OFF							
29-Apr	OFF							
30-Apr	0.50	300	150.0	12.0	7.4	36.8	Yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350