

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Jun-25

System Name: Johnson Creek Water Service		ID#: 41 01072		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Jun	0.30	0.40	OFF	OFF	OFF	OFF	0.40
2-Jun	OFF	OFF	OFF	OFF	OFF	0.02	0.02
3-Jun	0.00	0.24	OFF	OFF	OFF	OFF	0.24
4-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5-Jun	OFF	OFF	OFF	OFF	0.01	OFF	0.01
6-Jun	OFF	OFF	OFF	OFF	OFF	0.01	0.01
7-Jun	OFF	OFF	OFF	OFF	OFF	0.01	0.01
8-Jun	0.01	0.03	OFF	OFF	OFF	0.01	0.03
9-Jun	0.01	0.01	OFF	OFF	0.10	OFF	0.10
10-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11-Jun	OFF	OFF	OFF	OFF	0.01	0.01	0.01
12-Jun	0.04	OFF	OFF	0.11	OFF	OFF	0.11
13-Jun	OFF	OFF	OFF	OFF	0.01	0.01	0.01
14-Jun	0.01	OFF	OFF	0.01	0.01	0.01	0.01
15-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16-Jun	OFF	OFF	OFF	OFF	0.03	0.01	0.03
17-Jun	0.01	OFF	OFF	OFF	OFF	OFF	0.01
18-Jun	OFF	OFF	OFF	0.01	0.01	0.01	0.01
19-Jun	0.01	OFF	OFF	0.01	0.01	0.01	0.01
20-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22-Jun	OFF	OFF	OFF	OFF	OFF	0.01	0.01
23-Jun	0.01	0.01	OFF	OFF	OFF	0.01	0.01
24-Jun	0.01	0.01	0.01	OFF	OFF	0.01	0.01
25-Jun	0.01	0.01	OFF	OFF	OFF	OFF	0.01
26-Jun	OFF	OFF	OFF	OFF	0.01	0.01	0.01
27-Jun	0.01	OFF	OFF	OFF	OFF	OFF	0.01
28-Jun	OFF	OFF	OFF	OFF	0.01	0.01	0.01
29-Jun	0.20	OFF	OFF	OFF	OFF	OFF	0.20
30-Jun	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		

Notes:	PRINTED NAME: Curtis Olson	
	SIGNATURE: <i>Curtis Olson</i>	7/10/2025
	PHONE #: (503)-554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A		Inactivation
System Name: Johnson Creek Water Service		ID#: 41 01072		Month/Year: Jun-25		Disinfection <i>Giardia</i> Log Inactive:		1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Jun	0.40	300	120.0	13.0	7.3	32.5	Yes	80
2-Jun	0.40	300	120.0	15.0	7.4	29.5	Yes	80
3-Jun	0.50	300	150.0	13.0	7.4	34.1	Yes	80
4-Jun	OFF							
5-Jun	0.30	300	90.0	13.0	7.4	33.3	Yes	80
6-Jun	0.40	300	120.0	13.0	7.4	33.7	Yes	80
7-Jun	0.30	300	90.0	14.0	7.5	32.4	Yes	80
8-Jun	0.40	300	120.0	14.0	7.4	31.5	Yes	80
9-Jun	0.40	300	120.0	14.0	7.4	31.5	Yes	80
10-Jun	OFF							
11-Jun	0.60	300	180.0	14.0	7.4	32.3	Yes	80
12-Jun	0.80	300	240.0	14.0	7.4	33.0	Yes	80
13-Jun	0.90	300	270.0	14.0	7.6	36.0	Yes	80
14-Jun	1.00	300	300.0	14.0	7.5	35.0	Yes	80
15-Jun	OFF							
16-Jun	1.00	300	300.0	13.0	7.6	38.9	Yes	80
17-Jun	1.00	300	300.0	13.0	7.7	40.3	Yes	80
18-Jun	0.90	300	270.0	14.0	7.7	37.3	Yes	80
19-Jun	0.90	300	270.0	14.0	7.6	36.0	Yes	80
20-Jun	OFF							
21-Jun	OFF							
22-Jun	0.80	300	240.0	14.0	7.5	34.3	Yes	80
23-Jun	0.90	300	270.0	14.0	7.7	37.3	Yes	80
24-Jun	0.80	300	240.0	14.0	7.6	35.5	Yes	80
25-Jun	0.70	300	210.0	14.0	7.7	36.5	Yes	80
26-Jun	0.80	300	240.0	15.0	7.7	34.5	Yes	80
27-Jun	0.50	300	150.0	15.0	7.6	32.1	Yes	80
28-Jun	0.90	300	270.0	14.0	7.6	36.0	Yes	80
29-Jun	0.70	300	210.0	14.0	7.4	32.6	Yes	80
30-Jun	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350