

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Jul-25

System Name:		Johnson Creek Water Service		ID#: 41 01072		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Jul	OFF	OFF	OFF	0.01	0.01	0.01	0.01
2-Jul	OFF	OFF	OFF	OFF	0.01	0.01	0.01
3-Jul	0.01	0.01	OFF	OFF	OFF	OFF	0.01
4-Jul	OFF	OFF	OFF	OFF	0.01	0.01	0.01
5-Jul	0.01	0.01	OFF	OFF	OFF	OFF	0.01
6-Jul	OFF	OFF	OFF	OFF	OFF	0.01	0.01
7-Jul	0.01	0.01	0.01	OFF	OFF	0.01	0.01
8-Jul	0.01	OFF	OFF	0.01	OFF	OFF	0.01
9-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10-Jul	OFF	OFF	OFF	OFF	0.01	0.01	0.01
11-Jul	0.01	0.01	OFF	0.02	0.01	0.01	0.02
12-Jul	OFF	OFF	OFF	0.01	0.01	0.01	0.01
13-Jul	0.01	OFF	OFF	OFF	OFF	OFF	0.01
14-Jul	OFF	OFF	OFF	OFF	OFF	0.01	0.01
15-Jul	0.01	0.01	0.01	OFF	0.01	0.01	0.01
16-Jul	OFF	OFF	OFF	OFF	0.01	0.01	0.01
17-Jul	0.01	OFF	OFF	OFF	OFF	OFF	0.01
18-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19-Jul	OFF	OFF	OFF	OFF	0.01	0.01	0.01
20-Jul	0.01	0.20	OFF	OFF	OFF	OFF	0.20
21-Jul	OFF	OFF	OFF	OFF	OFF	0.01	0.01
22-Jul	0.01	0.01	0.01	OFF	OFF	OFF	0.01
23-Jul	OFF	OFF	OFF	OFF	OFF	0.01	0.01
24-Jul	0.01	0.01	OFF	OFF	OFF	OFF	0.01
25-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26-Jul	OFF	OFF	OFF	0.01	0.01	0.01	0.01
27-Jul	0.01	OFF	OFF	OFF	OFF	OFF	0.01
28-Jul	OFF	OFF	OFF	0.01	0.01	0.01	0.01
29-Jul	0.01	0.01	0.01	OFF	OFF	OFF	0.01
30-Jul	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31-Jul	OFF	OFF	OFF	OFF	0.01	0.01	0.010

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		

Notes:	PRINTED NAME: Curtis Olson	
	SIGNATURE: <i>Curtis Olson</i>	8/10/2025
	PHONE #: (503)-554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A		Inactivation
System Name: Johnson Creek Water Service		ID#: 41 01072	Month/Year: Jul-25		Disinfection <i>Giardia</i> Log Inactive:		1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Jul	0.60	300	180.0	15.0	7.7	33.7	Yes	80
2-Jul	0.60	300	180.0	14.0	7.8	37.4	Yes	80
3-Jul	0.60	300	180.0	14.0	7.7	36.1	Yes	80
4-Jul	0.70	301	210.7	15.0	7.7	34.1	Yes	80
5-Jul	0.80	300	240.0	15.0	7.7	34.5	Yes	80
6-Jul	1.00	300	300.0	15.0	7.8	36.6	Yes	80
7-Jul	0.60	300	180.0	15.0	7.8	35.0	Yes	80
8-Jul	0.90	300	270.0	15.0	7.8	36.2	Yes	80
9-Jul	OFF							
10-Jul	0.70	300	150.0	15.0	7.7	34.1	Yes	
11-Jul	0.70	300	210.0	15.0	7.8	35.4	Yes	80
12-Jul	OFF							
13-Jul	0.60	300	180.0	15.0	7.8	35.0	Yes	80
14-Jul	0.60	300	180.0	16.0	7.7	31.6	Yes	80
15-Jul	0.50	300	210.0	15.0	7.8	34.6	Yes	80
16-Jul	0.50	300	150.0	15.0	7.8	34.6	Yes	80
17-Jul	0.50	300	150.0	14.0	7.8	37.0	Yes	80
18-Jul	OFF							
19-Jul	0.40	300	120.0	15.0	7.8	34.2	Yes	80
20-Jul	0.50	300	150.0	15.0	7.8	34.6	Yes	80
21-Jul	0.40	300	150.0	15.0	7.7	33.0	Yes	80
22-Jul	0.60	300	180.0	15.0	7.7	33.7	Yes	80
23-Jul	0.50	300	150.0	15.0	7.6	32.1	Yes	80
24-Jul	0.40	300	120.0	16.0	7.8	32.0	Yes	80
25-Jul	OFF							
26-Jul	0.40	300	120.0	15.0	7.5	30.6	Yes	80
27-Jul	0.50	300	150.0	15.0	7.7	33.4	Yes	80
28-Jul	0.50	300	150.0	15.0	7.7	33.4	Yes	80
29-Jul	0.40	300	120.0	15.0	7.6	31.8	Yes	80
30-Jul	OFF							
31-Jul	0.30	300	180.0	16.0	7.6	29.4	Yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350