

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Aug-25

System Name:		Johnson Creek Water Service		ID#: 41 01072		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Aug	0.01	0.01	OFF	0.01	OFF	OFF	0.01
2-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3-Aug	OFF	OFF	OFF	OFF	OFF	0.01	0.01
4-Aug	0.01	0.01	0.01	OFF	OFF	0.01	0.01
5-Aug	0.01	0.01	OFF	OFF	OFF	OFF	0.01
6-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7-Aug	OFF	OFF	OFF	OFF	0.01	0.01	0.01
8-Aug	0.01	OFF	OFF	OFF	OFF	OFF	0.01
9-Aug	OFF	OFF	OFF	OFF	0.00	0.01	0.01
10-Aug	0.01	OFF	OFF	OFF	OFF	OFF	0.01
11-Aug	OFF	OFF	OFF	0.01	0.01	0.01	0.01
12-Aug	0.01	0.01	OFF	OFF	OFF	OFF	0.01
13-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14-Aug	OFF	OFF	OFF	OFF	0.01	0.01	0.01
15-Aug	0.01	0.15	OFF	0.01	OFF	OFF	0.15
16-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17-Aug	OFF	OFF	OFF	OFF	0.01	0.01	0.01
18-Aug	0.01	OFF	OFF	OFF	OFF	OFF	0.01
19-Aug	OFF	OFF	0.01	OFF	OFF	OFF	0.01
20-Aug	OFF	OFF	OFF	0.01	0.01	0.01	0.01
21-Aug	0.21	OFF	OFF	OFF	OFF	0.01	0.21
22-Aug	0.01	0.01	OFF	OFF	OFF	OFF	0.01
23-Aug	OFF	OFF	OFF	OFF	0.01	0.01	0.01
24-Aug	0.01	0.01	OFF	OFF	0.01	0.01	0.01
25-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27-Aug	OFF	OFF	OFF	OFF	0.01	0.01	0.01
28-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29-Aug	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30-Aug	OFF	OFF	OFF	0.01	0.01	0.01	0.01
31-Aug	OFF	OFF	OFF	OFF	0.01	0.03	0.025

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		

Notes:	PRINTED NAME: Curtis Olson	
	SIGNATURE: <i>Curtis Olson</i>	9/10/2025
	PHONE #: (503)-554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A		Inactivation
System Name: Johnson Creek Water Service		ID#: 41 01072	Month/Year: Aug-25		Disinfection <i>Giardia</i> Log Inactive:		1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Aug	0.30	300	90.0	16.0	7.6	29.4	Yes	80
2-Aug	OFF							
3-Aug	0.30	300	90.0	16.0	7.6	29.4	Yes	80
4-Aug	0.30	301	90.3	15.0	7.6	31.4	Yes	80
5-Aug	0.70	300	210.0	15.0	7.6	32.9	Yes	80
6-Aug	OFF							
7-Aug	0.70	300	210.0	15.0	7.5	31.7	Yes	80
8-Aug	0.70	300	210.0	15.0	7.5	31.7	Yes	80
9-Aug	0.70	300	210.0	15.0	7.4	30.5	Yes	80
10-Aug	0.70	300	150.0	16.0	7.3	27.5	Yes	
11-Aug	0.80	300	240.0	15.0	7.3	29.8	Yes	80
12-Aug	0.70	300	210.0	15.0	7.6	32.9	Yes	80
13-Aug	OFF							
14-Aug	0.60	300	180.0	16.0	7.4	28.2	Yes	80
15-Aug	0.70	300	210.0	16.0	7.4	28.6	Yes	80
16-Aug	OFF							
17-Aug	0.40	300	120.0	16.0	7.3	26.6	Yes	80
18-Aug	0.40	300	120.0	16.0	7.3	26.6	Yes	80
19-Aug	0.50	300	150.0	16.0	7.4	27.9	Yes	80
20-Aug	0.70	300	150.0	16.0	7.4	28.6	Yes	80
21-Aug	0.40	300	150.0	16.0	7.7	30.8	Yes	80
22-Aug	0.50	300	150.0	16.0	7.6	30.1	Yes	80
23-Aug	0.40	300	120.0	16.0	7.5	28.6	Yes	80
24-Aug	0.50	300	150.0	16.0	7.6	30.1	Yes	80
25-Aug	OFF							
26-Aug	OFF							
27-Aug	0.40	300	120.0	16.0	7.6	29.7	Yes	80
28-Aug	OFF							
29-Aug	OFF							
30-Aug	0.70	300	150.0	16.0	7.4	28.6	Yes	80
31-Aug	1.10	300	180.0	15.0	7.7	35.7	Yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350