

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Sep-25

System Name:		Johnson Creek Water Service		ID#: 41 01072		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Sep	OFF	OFF	OFF	0.01	0.01	OFF	0.01
2-Sep	OFF	OFF	OFF	0.01	0.01	0.01	0.01
3-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4-Sep	OFF	OFF	OFF	0.01	0.01	OFF	0.01
5-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6-Sep	OFF	OFF	OFF	OFF	0.01	0.01	0.01
7-Sep	OFF	OFF	OFF	0.01	OFF	OFF	0.01
8-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9-Sep	OFF	OFF	OFF	OFF	0.01	0.01	0.01
10-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12-Sep	OFF	OFF	OFF	0.01	0.01	0.01	0.01
13-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15-Sep	OFF	OFF	OFF	0.01	0.01	0.01	0.01
16-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17-Sep	OFF	OFF	OFF	OFF	0.01	OFF	0.01
18-Sep	OFF	OFF	OFF	OFF	0.01	0.01	0.01
19-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21-Sep	OFF	OFF	OFF	OFF	0.01	0.01	0.01
22-Sep	0.01	OFF	OFF	OFF	OFF	OFF	0.01
23-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24-Sep	OFF	OFF	OFF	OFF	OFF	0.01	0.01
25-Sep	0.01	OFF	OFF	OFF	OFF	0.01	0.01
26-Sep	0.01	OFF	OFF	OFF	OFF	0.01	0.01
27-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28-Sep	OFF	OFF	OFF	OFF	0.05	0.01	0.05
29-Sep	0.01	0.03	0.23	OFF	OFF	OFF	0.23
30-Sep	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		

Notes:	PRINTED NAME: Curtis Olson	
	SIGNATURE: <i>Curtis Olson</i>	10/10/2025
	PHONE #: (503)-554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A		Inactivation
System Name: Johnson Creek Water Service		ID#: 41 01072		Month/Year: Sep-25		Disinfection <i>Giardia</i> Log Inactive:		1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Sep	0.80	300	240.0	15.0	7.6	33.3	Yes	80
2-Sep	0.70	300	210.0	15.0	7.5	31.7	Yes	80
3-Sep	0.80	300	240.0	15.0	7.5	32.0	Yes	80
4-Sep	0.60	301	180.6	16.0	7.5	29.3	Yes	80
5-Sep	OFF							
6-Sep	0.50	300	150.0	15.0	7.4	29.8	Yes	80
7-Sep	0.50	300	150.0	16.0	7.6	30.1	Yes	80
8-Sep	OFF							
9-Sep	0.40	300	120.0	16.0	7.5	28.6	Yes	80
10-Sep	0.50	300	150.0	16.0	7.6	30.1	Yes	
11-Sep	OFF							80
12-Sep	0.50	300	150.0	15.0	7.5	31.0	Yes	80
13-Sep	OFF							
14-Sep	OFF							
15-Sep	0.50	300	210.0	15.0	7.5	31.0	Yes	80
16-Sep	OFF							
17-Sep	0.60	300	180.0	16.0	7.4	28.2	Yes	80
18-Sep	0.70	300	210.0	16.0	7.5	29.6	Yes	80
19-Sep	OFF							
20-Sep	OFF							
21-Sep	0.50	300	150.0	16.0	7.5	29.0	Yes	80
22-Sep	0.60	300	180.0	16.0	7.6	30.4	Yes	80
23-Sep	OFF							
24-Sep	0.50	300	150.0	16.0	7.4	27.9	Yes	80
25-Sep	0.40	300	120.0	16.0	7.4	27.6	Yes	
26-Sep	0.40	300	120.0	16.0	7.4	27.6	Yes	80
27-Sep	OFF							
28-Sep	0.80	300	240.0	15.0	7.3	29.8	Yes	80
29-Sep	0.80	300	240.0	15.0	7.3	29.8	Yes	80
30-Sep	OFF							

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dpw.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350