

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Oct-25

System Name:		Johnson Creek Water Service		ID#: 41 01072		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1-Oct	OFF	OFF	OFF	0.03	0.01	OFF	0.03
2-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5-Oct	OFF	OFF	OFF	OFF	0.01	OFF	0.01
6-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
8-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
9-Oct	0.01	0.01	OFF	OFF	OFF	OFF	0.01
10-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12-Oct	OFF	OFF	OFF	0.02	0.01	OFF	0.02
13-Oct	OFF	OFF	OFF	0.01	OFF	OFF	0.01
14-Oct	OFF	OFF	OFF	OFF	OFF	0.01	0.01
15-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
16-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
17-Oct	OFF	OFF	OFF	OFF	OFF	0.01	0.01
18-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19-Oct	OFF	OFF	OFF	OFF	0.06	OFF	0.06
20-Oct	OFF	OFF	OFF	OFF	OFF	0.01	0.01
21-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
22-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
23-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
24-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01
28-Oct	OFF	OFF	OFF	0.01	0.01	OFF	0.01
29-Oct	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30-Oct	OFF	OFF	OFF	0.01	0.04	OFF	0.04
31-Oct	OFF	OFF	OFF	OFF	0.01	0.01	0.01

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		

Notes:	PRINTED NAME: Curtis Olson	
	SIGNATURE: <i>Curtis Olson</i>	11/10/2025
	PHONE #: (503)-554-8333	CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form					WTP - : A		Inactivation	
System Name: Johnson Creek Water Service		ID#: 41 01072	Month/Year: Oct-25		Disinfection <i>Giardia</i> Log Inactive:		1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Oct	0.80	300	240.0	15.0	7.8	35.8	Yes	80
2-Oct	OFF							
3-Oct	OFF							
4-Oct	OFF							
5-Oct	0.40	300	120.0	15.0	7.4	29.5	Yes	80
6-Oct	OFF							
7-Oct	0.40	300	120.0	15.0	7.4	29.5	Yes	80
8-Oct	0.40	300	120.0	15.0	7.4	29.5	Yes	80
9-Oct	0.80	300	240.0	15.0	7.5	32.0	Yes	80
10-Oct	OFF							
11-Oct	OFF							80
12-Oct	0.80	300	240.0	15.0	7.4	30.9	Yes	80
13-Oct	0.80	300	240.0	14.0	7.4	33.0	Yes	80
14-Oct	0.80	300	240.0	14.0	7.6	35.5	Yes	80
15-Oct	0.70	300	210.0	14.0	7.2	30.3	Yes	80
16-Oct	0.60	300	180.0	15.0	7.4	30.2	Yes	80
17-Oct	0.60	300	180.0	14.0	7.5	33.5	Yes	80
18-Oct	OFF							
19-Oct	0.50	300	150.0	14.0	7.7	35.6	Yes	80
20-Oct	0.50	300	150.0	14.0	7.6	34.4	Yes	80
21-Oct	0.40	300	150.0	14.0	7.5	32.7	Yes	80
22-Oct	0.40	300	120.0	14.0	7.4	31.5	Yes	80
23-Oct	0.60	300	180.0	14.0	7.5	33.5	Yes	80
24-Oct	OFF							
25-Oct	OFF							
26-Oct	OFF							
27-Oct	0.40	300	120.0	14.0	7.4	31.5	Yes	80
28-Oct	0.50	300	150.0	14.0	7.4	31.9	Yes	80
29-Oct	OFF							
30-Oct	0.40	300	150.0	14.0	7.4	31.5	Yes	80
31-Oct	0.40	300	180.0	14.0	7.5	32.7	Yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350