

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Lincoln

Conventional or Direct Filtration

Month/Year:

Dec-25

System Name:	Johnson Creek Water Service		ID#: 41 01072				WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1-Dec	0.24	OFF	OFF	OFF	OFF	OFF	0.24	
2-Dec	OFF	OFF	OFF	OFF	OFF	0.01	0.01	
3-Dec	0.01	OFF	OFF	OFF	OFF	0.01	0.01	
4-Dec	0.01	0.01	OFF	OFF	OFF	OFF	0.01	
5-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6-Dec	OFF	OFF	OFF	0.01	0.01	0.01	0.01	
7-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11-Dec	OFF	OFF	OFF	0.01	0.01	0.01	0.01	
12-Dec	0.01	OFF	OFF	OFF	OFF	OFF	0.01	
13-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15-Dec	OFF	OFF	OFF	OFF	OFF	0.01	0.01	
16-Dec	0.01	OFF	OFF	0.01	0.01	OFF	0.01	
17-Dec	OFF	OFF	OFF	OFF	0.15	OFF	0.15	
18-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21-Dec	OFF	OFF	OFF	OFF	0.01	0.01	0.01	
22-Dec	0.02	OFF	OFF	OFF	OFF	OFF	0.02	
23-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25-Dec	OFF	OFF	OFF	OFF	OFF	0.01	0.01	
26-Dec	0.01	0.10	OFF	OFF	OFF	OFF	0.10	
27-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29-Dec	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30-Dec	OFF	OFF	OFF	OFF	OFF	0.05	0.05	
31-Dec	0.04	0.03	OFF	OFF	OFF	0.03	0.04	

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?

Yes / No

All 4-hour turbidity readings ≤ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
≥ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Curtis Olson

SIGNATURE: *Curtis Olson*

1/10/2026

PHONE #: (503)-554-8333

CERT #: T216644

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name:	Johnson Creek Water Service	ID#: 41 01072	Month/Year:	Dec-25	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-Dec	0.40	300	120.0	12.0	7.5	37.7	Yes	80
2-Dec	0.30	300	90.0	12.0	7.3	34.8	Yes	80
3-Dec	0.40	300	120.0	12.0	7.4	36.4	Yes	80
4-Dec	0.70	301	210.7	12.0	7.4	37.6	Yes	80
5-Dec	OFF							
6-Dec	0.60	300	180.0	12.0	7.4	37.2	Yes	80
7-Dec	OFF							
8-Dec	OFF							
9-Dec	OFF							
10-Dec	OFF							
11-Dec	0.50	300	150.0	12.0	7.5	38.1	Yes	80
12-Dec	0.40	300	120.0	12.0	7.6	39.0	Yes	80
13-Dec	OFF							
14-Dec	OFF							
15-Dec	0.50	300	210.0	12.0	7.5	38.1	Yes	80
16-Dec	0.40	300	120.0	13.0	7.5	35.0	Yes	80
17-Dec	0.60	300	180.0	12.0	7.6	39.9	Yes	80
18-Dec	OFF							
19-Dec	OFF							
20-Dec	OFF							
21-Dec	0.60	300	150.0	11.0	7.4	39.7	Yes	80
22-Dec	0.60	300	180.0	12.0	7.4	37.2	Yes	80
23-Dec	OFF							
24-Dec	OFF							
25-Dec	0.70	300	210.0	12.0	7.3	36.4	Yes	80
26-Dec	0.80	300	240.0	12.0	7.5	39.4	Yes	80
27-Dec	OFF							
28-Dec	OFF							
29-Dec	OFF							
30-Dec	0.50	300	150.0	11.0	7.4	39.3	Yes	80
31-Dec	0.70	300	150.0	11.0	7.5	41.6	Yes	80

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350