

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Jan-26

System Name: Johnson Creek Water Service		ID#: 41 01072					WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1-Jan	0.15	0.15	OFF	OFF	OFF	OFF	0.15	
2-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4-Jan	OFF	OFF	OFF	OFF	0.04	OFF	0.04	
5-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7-Jan	OFF	OFF	OFF	OFF	0.08	0.04	0.08	
8-Jan	0.28	OFF	OFF	OFF	OFF	0.04	0.28	
9-Jan	0.03	OFF	OFF	OFF	0.04	0.03	0.04	
10-Jan	0.03	0.03	0.04	OFF	OFF	OFF	0.04	
11-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14-Jan	OFF	OFF	OFF	OFF	OFF	0.01	0.01	
15-Jan	0.01	0.01	0.01	0.15	OFF	OFF	0.15	
16-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18-Jan	OFF	OFF	OFF	OFF	0.01	0.02	0.02	
19-Jan	0.01	OFF	OFF	OFF	OFF	OFF	0.01	
20-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21-Jan	OFF	OFF	OFF	OFF	0.01	0.01	0.01	
22-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27-Jan	OFF	OFF	OFF	OFF	OFF	0.08	0.08	
28-Jan	0.01	0.01	0.01	OFF	OFF	OFF	0.01	
29-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31-Jan	OFF	OFF	OFF	OFF	OFF	OFF	OFF	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Curtis Olson
	SIGNATURE: <i>Curtis Olson</i> 2/8/2026
	PHONE #: (503)-554-8333 CERT #: T216644

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name:	Johnson Creek Water Service	ID#: 41 01072	Month/Year:	Jan-26	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1-Jan	0.80	300	240.0	11.0	7.6	43.6	Yes	80
2-Jan	OFF							
3-Jan	OFF							
4-Jan	0.90	301	270.9	10.0	7.5	45.4	Yes	80
5-Jan	OFF							
6-Jan	OFF							
7-Jan	0.90	300	270.0	10.0	7.6	47.1	Yes	80
8-Jan	0.90	300	270.0	10.0	7.5	45.4	Yes	80
9-Jan	0.90	300	270.0	10.0	7.6	47.1	Yes	80
10-Jan	0.80	300	150.0	10.0	7.5	44.9	Yes	
11-Jan	OFF							80
12-Jan	OFF							
13-Jan	OFF							
14-Jan	0.50	300	150.0	11.0	7.4	39.3	Yes	80
15-Jan	0.70	300	210.0	11.0	7.6	43.1	Yes	80
16-Jan	OFF							
17-Jan	OFF							
18-Jan	0.70	300	210.0	10.0	7.6	46.0	Yes	80
19-Jan	0.90	300	270.0	10.0	7.8	50.6	Yes	80
20-Jan	OFF							
21-Jan	0.80	300	150.0	10.0	7.8	50.0	Yes	80
22-Jan	OFF							
23-Jan	OFF							
24-Jan	OFF							
25-Jan	OFF							
26-Jan	OFF							
27-Jan	0.60	300	180.0	11.0	7.6	42.6	Yes	80
28-Jan	0.80	300	240.0	11.0	7.8	46.8	Yes	80
29-Jan	OFF							
30-Jan	OFF							
31-Jan	OFF							

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350