

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Lincoln

Conventional or Direct Filtration

Month/Year: Mar-26

System Name: Johnson Creek Water Service		ID#: 41 01072					WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1-Mar	OFF	OFF	OFF	OFF	0.010	0.010	0.010	
2-Mar	0.010	0.140	OFF	OFF	OFF	OFF	0.140	
3-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4-Mar	OFF	OFF	OFF	OFF	0.060	0.010	0.060	
5-Mar	0.010	OFF	OFF	OFF	OFF	OFF	0.010	
6-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10-Mar	OFF	OFF	OFF	OFF	OFF	0.040	0.040	
11-Mar	0.030	0.010	0.100	OFF	OFF	OFF	0.100	
12-Mar	0.030	0.040	OFF	OFF	OFF	OFF	0.040	
13-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16-Mar	OFF	OFF	OFF	OFF	OFF	0.070	0.070	
17-Mar	0.010	0.010	0.010	0.010	OFF	OFF	0.010	
18-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20-Mar	OFF	OFF	OFF	OFF	OFF	0.010	0.010	
21-Mar	0.010	0.030	0.080	OFF	OFF	OFF	0.080	
22-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25-Mar	OFF	OFF	OFF	OFF	0.230	0.150	0.230	
26-Mar	OFF	OFF	OFF	OFF	OFF	0.230	0.230	
27-Mar	0.020	0.010	0.010	0.240	OFF	OFF	0.240	
28-Mar	OFF	OFF	OFF	OFF	OFF	0.050	0.050	
29-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31-Mar	OFF	OFF	OFF	OFF	OFF	OFF	OFF	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Curtis Olson
	SIGNATURE: <i>Curtis Olson</i> 4/6/2026
	PHONE #: (503)-554-8333 CERT #: T216644

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - : A	Inactivation
System Name:	Johnson Creek Water Service	ID#: 41 01072	Month/Year:	Mar-26	Disinfection <i>Giardia</i> Log Inactive:	1	

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1-Mar	0.40	300	120.0	9.0	7.3	42.8	Yes	80
2-Mar	0.40	300	120.0	9.0	7.3	42.8	Yes	80
3-Mar	OFF							
4-Mar	0.40	301	120.4	10.0	7.3	40.1	Yes	80
5-Mar	0.40	300	120.0	9.0	7.4	44.3	Yes	80
6-Mar	OFF							
7-Mar	OFF							
8-Mar	OFF							
9-Mar	OFF							
10-Mar	0.30	300	150.0	9.0	7.3	42.3	Yes	80
11-Mar	0.50	300	150.0	9.0	7.5	46.4	Yes	80
12-Mar	0.40	300	120.0	10.0	7.4	41.5	Yes	80
13-Mar	OFF							
14-Mar	OFF							
15-Mar	OFF							
16-Mar	0.40	300	120.0	10.0	7.3	40.1	Yes	80
17-Mar	0.40	300	120.0	10.0	7.3	40.1	Yes	80
18-Mar	OFF							
19-Mar	OFF							
20-Mar	0.30	300	150.0	11.0	7.3	37.1	Yes	80
21-Mar	0.50	300	150.0	11.0	7.5	40.7	Yes	80
22-Mar	OFF							
23-Mar	OFF							
24-Mar	OFF							
25-Mar	0.40	300	120.0	12.0	7.3	35.2	Yes	80
26-Mar	0.70	300	210.0	11.0	7.3	38.8	Yes	80
27-Mar	0.90	300	270.0	10.0	7.4	43.9	Yes	80
28-Mar	0.90	300	270.0	10.0	7.4	43.9	Yes	80
29-Mar	OFF							
30-Mar	OFF							
31-Mar	OFF							

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350