

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Douglas  
Month/Year: Feb-24

System Name:	USFS Steamboat Work Center			ID#: 41	01091		WTP: TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1								
2	pol	pol	pol	0.02	pol	pol		0.02
3								
4								
5	pol	pol	pol	0.03	pol	pol		0.03
6								
7	pol	pol	pol	0.03	pol	pol		0.03
8								
9	pol	pol	pol	0.03	pol	pol		0.03
10								
11								
12	pol	pol	pol	0.03	pol	pol		0.03
13								
14	pol	pol	pol	0.03	pol	pol		0.03
15								
16	pol	pol	pol	0.03	pol	pol		0.03
17								
18								
19	pol	pol	pol	0.04	pol	pol		0.04
20								
21	pol	pol	pol	0.03	pol	pol		0.03
22								
23	pol	pol	pol	0.03	pol	pol		0.03
24								
25								
26	pol	pol	pol	0.04	pol	pol		0.04
27								
28	pol	pol	pol	0.03	pol	pol		0.03
29								
30								
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>Jonathan Woody</i>	3-7-24 23-Oct
	PHONE #: ( 541 ) 643-6137	CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Steamboat Work Center						ID#: 41		01091		Month/Year: Feb-24		WTP - : A	
Disinfection <i>Giardia</i> Log Inactiv: 0.5													

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		60						36
2	1.1	60	66.0	12.0	7.30	19.0	Yes	36
3		60						36
4		60						36
5	0.9	60	54.0	11.0	7.30	19.8	yes	36
6		60						36
7	1.1	60	66.0	11.0	7.30	20.3	yes	36
8		60						36
9	1.1	60	66.0	11.0	7.30	20.3	yes	36
10		60						36
11	1.1	60	66.0	11.0	7.40	21.0	yes	36
12		60						36
13		60						36
14	1	60	60.0	11.0	7.40	20.8	yes	36
15		60						36
16	1.1	60	66.0	11.0	7.40	21.0	yes	36
17		60						36
18		60						36
19	1.1	60	66.0	11.0	7.40	21.0	yes	36
20		60						36
21	1.1	60	66.0	11.0	7.40	21.0	yes	36
22		60						36
23	1.1	60	66.0	11.0	7.40	21.0	yes	36
24		60						36
25		60						36
26	1.1	60	66.0	11.0	7.30	20.3	yes	36
27		60						36
28	1.1	60	66.0	11.0	7.40	21.0	yes	36
29		60						36
30		60						36
31		60						36

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.