

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Mar-24**

System Name: **USFS Steamboat Work Center** **ID#: 41** **01091** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	pol	pol	pol	0.03	pol	pol	0.03
2							
3							
4	pol	pol	pol	0.03	pol	pol	0.03
5							
6	pol	pol	pol	0.03	pol	pol	0.03
7							
8	pol	pol	pol	0.03	pol	pol	0.03
9							
10							
11	pol	pol	pol	0.03	pol	pol	0.03
12							
13	pol	pol	pol	0.03	pol	pol	0.03
14							
15							
16	pol	pol	pol	0.03	pol	pol	0.03
17							
18	pol	pol	pol	0.03	pol	pol	0.03
19							
20	pol	pol	pol	0.03	pol	pol	0.03
21							
22	pol	pol	pol	0.03	polo	pol	0.03
23							
24							
25	pol	pol	pol	0.03	pol	pol	0.03
26							
27	pol	pol	pol	0.03	pol	pol	0.03
28							
29	pol	pol	pol	0.03	pol	pol	0.03
30							
31	pol	pol	pol	0.03	pol	pol	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>Jonathan Woody</i>	4-8-24 23-Oct
	PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Efl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Steamboat Work Center	ID#: 41	01091	Month/Year: Mar-24	Disinfection <i>Giardia</i> Log Inactiv: 0.5
---	---------	-------	--------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	60	72.0	11.0	7.40	21.2	yes	36
2		60						36
3		60						36
4	0.8	60	48.0	9.0	7.40	23.2	yes	36
5		60						36
6	1.1	60	66.0	10.0	7.50	23.2	yes	36
7		60						36
8	1.1	60	66.0	10.0	7.50	23.2	yes	36
9		60						36
10		60						36
11	0.9	60	54.0	10.0	7.50	22.7	yes	36
12		60						36
13	1	60	60.0	10.0	7.40	22.2	yes	36
14		60						36
15		60						36
16	1.1	60	66.0	11.0	7.50	21.8	yes	36
17		60						36
18	1.2	60	72.0	11.0	7.50	22.0	yes	36
19		60						36
20	1.4	60	84.0	11.0	7.40	21.7	yes	36
21		60						36
22	1.3	60	78.0	12.0	7.30	19.4	yes	36
23		60						36
24		60						36
25	1.1	60	66.0	12.0	7.30	19.0	yes	36
26		60						36
27	1.4	60	84.0	11.0	7.40	21.7	yes	36
28		60						36
29	1.1	60	66.0	11.0	7.40	21.0	yes	36
30		60						36
31	1.3	60	78.0	12.0	7.30	19.4	yes	36

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013