

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jul-25**

System Name: USFS Steamboat Work Center		ID#: 41		01091		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2	pol	pol	pol	0.04	pol	pol	0.04
3							
4	pol	pol	pol	0.06	pol	pol	0.06
5							
6							
7	pol	pol	pol	0.08	pol	pol	0.08
8							
9	pol	pol	pol	0.11	pol	pol	0.11
10							
11	pol	pol	pol	0.07	pol	pol	0.07
12							
13							
14	pol	pol	pol	0.08	pol	pol	0.08
15	pol	pol	pol	0.03	pol	pol	0.03
16	pol	pol	pol	0.07	pol	pol	0.07
17							
18	pol	pol	pol	0.05	pol	pol	0.05
19							
20							
21	pol	pol	pol	0.04	pol	pol	0.04
22							
23	pol	pol	pol	0.06	pol	pol	0.06
24							
25	pol	pol	pol	0.05	pol	pol	0.05
26							
27							
28	pol	pol	pol	0.03	pol	pol	0.03
29							
30	pol	pol	pol	0.03	pol	pol	0.03
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		
Notes:		PRINTED NAME: Jonathan Woody	
		SIGNATURE: <i>Jonathan Woody</i>	
		PHONE #: (541) 643-6137	
		8-10-25	
		CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP - :
A
System Name: USFS Steamboat Work Center

ID#: 41

01091
Month/Year:
Jul-25
**Disinfection *Giardia*
Log Inactiv:**
0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH		CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		60						36
2	1.2	60	72.0	16.0	7.60	16.3	yes	36
3		60						36
4	1.1	60	66.0	18.0	7.60	14.1	yes	36
5		60						36
6		60						36
7	0.8	60	48.0	16.0	7.50	15.0	yes	36
8		60						36
9	0.9	60	54.0	17.0	7.40	13.7	yes	36
10		60						36
11	0.9	60	54.0	18.0	7.40	12.8	yes	36
12		60						36
13		60						36
14	0.7	60	42.0	20.0	7.50	11.3	yes	36
15	0.7	60	42.0	17.0	7.50	13.9	yes	36
16	1.1	60	66.0	18.0	7.70	14.6	yes	36
17		60						36
18	0.9	60	54.0	18.0	7.60	13.8	yes	36
19		60						36
20		60						36
21	0.9	60	54.0	18.0	7.70	14.3	yes	36
22		60						36
23	0.8	60	48.0	18.0	7.80	14.7	yes	36
24		60						36
25	0.7	60	42.0	18.0	7.70	14.0	yes	36
26		60						36
27		60						36
28	0.9	60	54.0	19.0	7.90	14.4	yes	36
29		60						36
30	0.9	60	54.0	19.0	7.70	13.4	yes	36
31		60						36

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013