

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Aug-25

System Name:	USFS Steamboat Work Center			ID#: 41	01091	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	pol	pol	pol	0.03	pol	pol	0.03
2							
3							
4	pol	pol	pol	0.03	pol	pol	0.03
5							
6	pol	pol	pol	0.03	pol	pol	0.03
7							
8	pol	pol	pol	0.03	pol	pol	0.03
9							
10							
11	pol	pol	pol	0.05	pol	pol	0.05
12							
13	pol	pol	pol	0.03	pol	pol	0.03
14							
15	pol	pol	pol	0.04	pol	pol	0.04
16							
17							
18	pol	pol	pol	0.05	pol	pol	0.05
19							
20	pol	pol	pol	0.04	pol	pol	0.04
21							
22	pol	pol	pol	0.04	pol	pol	0.04
23							
24							
25	pol	pol	pol	0.04	pol	pol	0.04
26							
27	pol	pol	pol	0.04	pol	pol	0.04
28							
29	pol	pol	pol	0.04	pol	pol	0.04
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> PHONE #: (541) 643-6137	
		9-10-2025 CERT #: 7232	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Steamboat Work Center ID#: 41 01091 Month/Year: Aug-25 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.7	60	42.0	20.0	7.70	12.2	Yes	36
2		60						36
3		60						36
4	0.7	60	42.0	18.0	7.60	13.5	Yes	36
5		60						36
6	0.7	60	42.0	18.0	7.70	14.0	Yes	36
7		60						36
8	1.1	60	66.0	17.0	7.50	14.5	Yes	36
9		60						36
10		60						36
11	0.8	60	48.0	20.0	7.80	12.8	Yes	36
12		60						36
13	0.9	60	54.0	20.0	7.80	13.0	Yes	36
14		60						36
15	1.1	60	66.0	18.0	7.40	13.1	Yes	36
16		60						36
17		60						36
18	0.7	60	42.0	19.0	7.60	12.6	Yes	36
19		60						36
20	0.8	60	48.0	21.0	7.60	11.1	Yes	36
21		60						36
22	0.8	60	48.0	20.0	7.90	13.3	Yes	36
23		60						36
24		60						36
25	0.7	60	42.0	20.0	7.60	11.8	Yes	36
26		60						36
27	0.8	60	48.0	19.0	7.90	14.2	Yes	36
28		60						36
29	0.8	60	48.0	19.0	7.80	13.7	Yes	36
30		60						36
31		60						36

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013