

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Sep-25

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2	pol	pol	pol	0.08	pol	pol	0.08
3	pol	pol	pol	0.08	pol	pol	0.07
4							
5	pol	pol	pol	0.08	pol	pol	0.08
6							
7							
8	pol	pol	pol	0.07	pol	pol	0.07
9	pol	pol	pol	0.06	pol	pol	0.06
10							
11							
12	pol	pol	0.06	0.06	pol	pol	0.06
13							
14							
15	pol	pol	0.10	0.08	pol	pol	0.10
16							
17	pol	pol	pol	0.09	pol	pol	0.09
18							
19	pol	pol	pol	0.08	pol	pol	0.08
20							
21							
22	pol	pol	pol	0.08	pol	pol	0.08
23							
24	pol	pol	pol	0.10	pol	pol	0.10
25							
26	pol	pol	pol	0.06	pol	pol	0.06
27							
28							
29	pol	pol	pol	0.05	pol	pol	0.05
30							
31							

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?☒ Yes / ☐ NoAll 4-hour turbidity readings $\leq$ 1 NTU?☒ Yes / ☐ NoAll turbidity readings $<$ IFE² triggers☒ Yes / ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)☒ Yes / ☐ NoAll Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?☒ Yes / ☐ No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

PHONE #: (541) 643-6137

10-9-25

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

						WTP - :		A
System Name:		ID#:		01091	Month/Year:	Jun-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		60						36
2	1.1	60	66.0	16.0	7.40	14.9	Yes	36
3	1	60	60.0	18.0	7.50	13.4	Yes	36
4		60						36
5	0.8	60	48.0	17.0	7.60	14.6	Yes	36
6		60						36
7		60						36
8	0.7	60	42.0	16.0	7.60	15.4	Yes	36
9	0.8	60	48.0	15.0	7.70	17.3	Yes	36
10		60						36
11		60						36
12	1.06	60	63.6	15.0	7.80	18.4	Yes	36
13		60						36
14		60						36
15	1.1	60	66.0	14.0	7.40	17.1	Yes	36
16		60						36
17	1.1	60	66.0	16.0	7.40	14.9	Yes	36
18		60						36
19	1	60	60.0	14.0	7.50	17.5	Yes	36
20		60						36
21		60						36
22	1.1	60	66.0	14.0	7.50	17.7	Yes	36
23		60						36
24	1.1	60	66.0	15.0	7.70	17.9	Yes	36
25		60						36
26	1.1	60	66.0	13.0	7.80	21.2	Yes	36
27		60						36
28		60						36
29	0.9	60	54.0	16.0	7.70	16.3	Yes	36
30		60						36
31		60						36

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013