

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Douglas

Conventional or Direct Filtration

Month/Year:

Oct-25

System Name:		USFS Steamboat Work Center		ID#: 41	01091	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	pol	pol	pol	0.05	pol	pol	0.05
2							
3	pol	pol	pol	0.05	pol	pol	0.05
4							
5							
6	pol	pol	pol	0.04	pol	pol	0.04
7							
8	pol	pol	pol	0.04	pol	pol	0.04
9							
10	pol	pol	pol	0.04	pol	pol	0.04
11							
12							
13							
14	pol	pol	pol	0.05	pol	pol	0.05
15	pol	pol	pol	0.05	pol	pol	0.05
16							
17	pol	pol	pol	0.06	pol	pol	0.06
18							
19							
20	pol	pol	pol	0.04	pol	pol	0.04
21							
22	pol	pol	pol	0.04	pol	pol	0.04
23							
24	pol	pol	pol	0.04	pol	pol	0.04
25							
26							
27	pol	pol	pol	0.05	pol	pol	0.05
28							
29	pol	pol	pol	0.10	pol	pol	0.10
30							
31	pol	pol	pol	0.10	pol	pol	0.10

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>John Woody</i>	11-10-25
	PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:	USFS Steamboat Work Center	ID#: 41	01091	Month/Year:	Oct-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	----------------------------	---------	-------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	60	48.0	15.0	7.60	16.6	Yes	36
2		60						36
3	1.2	60	72.0	14.0	7.60	18.6	Yes	36
4		60						36
5		60						36
6	1.2	60	72.0	14.0	7.60	18.6	Yes	36
7		60						36
8	1.2	60	72.0	12.0	7.50	20.6	Yes	36
9		60						36
10	1.5	60	90.0	14.0	7.60	19.2	Yes	36
11		60						36
12		60						36
13		60						36
14	1.2	60	72.0	13.0	7.80	21.4	Yes	36
15	0.9	60	54.0	13.0	7.60	19.2	Yes	36
16		60						36
17	0.9	60	54.0	12.0	7.50	19.9	Yes	36
18		60						36
19		60						36
20	1	60	60.0	13.0	8.10	23.4	Yes	36
21		60						36
22	1.5	60	90.0	13.0	7.50	19.8	Yes	36
23		60						36
24	1.5	60	90.0	11.0	7.90	26.2	Yes	36
25		60						36
26		60						36
27	1.6	60	96.0	12.0	7.60	22.3	Yes	36
28		60						36
29	1.1	60	66.0	14.0	7.50	17.7	Yes	36
30		60						36
31	1.2	60	72.0	12.0	7.70	22.1		36

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013