

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: **Douglas**  
 Month/Year: **Nov-21**

System Name:	USFS Tiller Ranger Station		ID#: 41	01092		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	0.05	0.03	0.03	0.03	0.05
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	POL	POL	POL	POL	POL
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	0.03	0.04	0.04	POL	0.08
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	0.07	0.03	POL	POL	0.07
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	0.05	POL	POL	POL	0.05
17	POL	POL	POL	POL	0.06	POL	0.06
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	0.05	0.03	POL	POL	0.05
21	POL	POL	POL	POL	POL	POL	POL
22	POL	POL	POL	0.10	POL	POL	0.10
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	0.03	0.02	0.02	0.26
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	POL	POL	POL	POL
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	POL	POL	POL	POL	POL
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE2 triggers <input checked="" type="checkbox"/> Yes / No		

Notes:

PRINTED NAME: Jonathan Woody  
 SIGNATURE: *Jonathan Woody*  
 PHONE #: ( 641 ) 643-6137  
 DATE: 12-7-21  
 CERT #: 7232

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings/ maximums. 2 IFE = Individ. Filter ETL (333-061-0040(1)(a)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Tiller Ranger Station ID#: 41 01092 Month/Year: Nov-21 Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl2 Residual at 1st User ( C ) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	86	POL	POL	POL	POL	POL	28
2	0.6	86	51.6	14.0	8.20	31.0	YES	28
3	POL	86	POL	POL	POL	POL	POL	28
4	POL	86	POL	POL	POL	POL	POL	28
5	POL	86	POL	POL	POL	POL	POL	28
6	0.9	86	77.4	14.0	8.30	33.0	YES	28
7	0.7	86	60.2	14.0	8.20	32.0	YES	28
8	POL	86	POL	POL	POL	POL	POL	28
9	POL	86	POL	POL	POL	POL	POL	28
10	POL	86	POL	POL	POL	POL	POL	28
11	POL	86	POL	POL	POL	POL	POL	28
12	0.6	86	51.6	13.0	7.90	26.0	YES	28
13	0.6	86	51.6	13.0	8.10	31.0	YES	28
14	0.8	86	68.8	14.0	7.90	32.0	YES	28
15	POL	86	POL	POL	POL	POL	POL	28
16	1	86	86.0	13.0	8.10	33.0	YES	28
17	0.8	86	68.8	13.0	8.30	32.0	YES	28
18	1.2	86	103.2	13.0	8.00	28.0	YES	28
19	POL	86	POL	POL	POL	POL	POL	28
20	0.9	86	77.4	14.0	7.80	27.0	YES	28
21	0.6	86	51.6	14.0	7.90	26.0	YES	28
22	0.7	86	60.2	14.0	8.00	26.0	YES	28
23	POL	86	POL	POL	POL	POL	POL	28
24	0.8	86	68.8	14.0	7.80	26.0	YES	28
25	1.6	86	137.6	14.0	7.90	29.0	YES	28
26	POL	86	POL	POL	POL	POL	POL	28
27	1.5	86	129.0	11.0	8.40	35.0	YES	28
28	0.7	86	60.2	12.0	8.40	32.0	YES	28
29	POL	86	POL	POL	POL	POL	POL	28
30	POL	86	POL	POL	POL	POL	POL	28
31		86						28

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012