

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Feb-22

System Name:	USFS Tiller Ranger Station		ID#: 41	01092			WTP: TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	POL	0.08	0.03	0.13
3	0.03	POL	POL	POL	POL	POL	0.03
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	POL	POL	POL	POL	POL
6	POL	POL	0.03	0.05	POL	POL	0.05
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	POL	POL	POL	POL
15	POL	POL	0.06	0.06	0.03	0.03	0.07
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	POL	POL	POL	POL	POL
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	0.04	POL	POL	0.04
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	0.05	POL	POL	0.14
28	POL	POL	POL	POL	0.05	0.04	0.10
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
All turbidity readings < IFE2 triggers	<input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes:		PRINTED NAME: Jonathan Woody	DATE: 3/9/2022
		SIGNATURE: <i>Jonathan Woody</i>	CERT #: 7232
		PHONE #: (541) 643-6137	

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = In-Field Filter BTL (333-891-9949)(1)(4)(B&C)

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	USFS Tiller Ranger Station	ID#: 41	01092	Month/Year:	Feb-22	Disinfection Giardia Log Inactiv:	0.5
--------------	----------------------------	---------	-------	-------------	--------	-----------------------------------	-----

Date / Time	Minimum Cl2 Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	POL	86	POL	POL	POL	POL	POL	28
2	0.7	86	60.2	10.0	8.40	32.0	YES	28
3	POL	86	POL	POL	POL	POL	POL	28
4	POL	86	POL	POL	POL	POL	POL	28
5	0.9	86	77.4	10.0	8.40	33.0	YES	28
6	1.1	86	94.6	10.0	8.40	33.0	YES	28
7	POL	86	POL	POL	POL	POL	POL	28
8	POL	86	POL	POL	POL	POL	POL	28
9	POL	86	POL	POL	POL	POL	POL	28
10	POL	86	POL	POL	POL	POL	POL	28
11	POL	86	POL	POL	POL	POL	POL	28
12	1	86	86.0	10.0	8.30	33.0	YES	28
13	0.9	86	77.4	13.0	8.30	33.0	YES	28
14	POL	86	POL	POL	POL	POL	POL	28
15	0.8	86	68.8	13.0	8.40	32.0	YES	28
16	POL	86	POL	POL	POL	POL	POL	28
17	POL	86	POL	POL	POL	POL	POL	28
18	POL	86	POL	POL	POL	POL	POL	28
19	1.1	86	94.6	12.0	8.40	33.0	YES	28
20	0.8	86	68.8	13.0	8.30	32.0	YES	28
21	0.6	86	51.6	13.0	8.40	31.0	YES	28
22	POL	86	POL	POL	POL	POL	POL	28
23	POL	86	POL	POL	POL	POL	POL	28
24	POL	86	POL	POL	POL	POL	POL	28
25	1.6	86	137.6	14.0	8.40	35.0	YES	28
26	1.2	86	103.2	13.0	8.20	33.0	YES	28
27	1.4	86	120.4	13.0	8.30	34.0	YES	28
28	1.3	86	111.8	13.0	8.30	34.0	YES	28
29		86						28
30		86						28
31		86						28

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012