

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Month/Year: Jan-23

Conventional or Direct Filtration

WTP : TP - A

System Name:	USFS Tiller Ranger Station			ID#: 41	01092		Highest Reading of the Day 1 [NTU]
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	0.05	0.06	0.05	0.08
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	POL	POL	POL	POL	POL
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	0.06	0.06	0.05	0.07
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	0.06	0.06	POL	0.07
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	POL	POL	POL	POL
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	0.06	0.05	0.05	0.09
21	POL	POL	POL	POL	POL	POL	POL
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	POL	POL	POL	POL
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	POL	0.08	0.26	0.08	0.27
31	0.07	POL	POL	POL	POL	POL	0.07

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?

Yes  No

All 4-hour turbidity readings ≤ 1 NTU?

Yes  No

All turbidity readings < IFE2 triggers

Yes  No

CT's met everyday?  
(see back)

Yes  No

All Cl2 residual at entry point  
≥ 0.2 mg/l?

Yes  No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

DATE: 2-7-23

PHONE #: ( 541 ) 643-6137

CERT #: 7232

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

<b>System Name:</b> USFS Tiller Ranger Station	<b>ID#:</b> 41	01092	<b>Month/Year:</b> Jan-23	<b>WTP - :</b> A	<b>Disinfection Giardia Log Inactiv:</b> 0.5
--	----------------	-------	---------------------------	------------------	--

Date / Time	Minimum Cl2 Residual at 1st User ( C ) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	86	POL	POL	POL	POL	POL	28
2	1.1	86	94.6	14.0	8.30	33.0	YES	28
3	0.6	86	51.6	13.0	8.30	31.0	YES	28
4	POL	86	POL	POL	POL	POL	POL	28
5	POL	86	POL	POL	POL	POL	POL	28
6	POL	86	POL	POL	POL	POL	POL	28
7	POL	86	POL	POL	POL	POL	POL	28
8	0.6	86	51.6	13.0	8.20	31.0	YES	28
9	POL	86	POL	POL	POL	POL	POL	28
10	POL	86	POL	POL	POL	POL	POL	28
11	1.3	86	111.8	12.0	8.00	28.0	YES	28
12	POL	86	POL	POL	POL	POL	POL	28
13	POL	86	POL	POL	POL	POL	POL	28
14	POL	86	POL	POL	POL	POL	POL	28
15	POL	86	POL	POL	POL	POL	POL	28
16	POL	86	POL	POL	POL	POL	POL	28
17	POL	86	POL	POL	POL	POL	POL	28
18	POL	86	POL	POL	POL	POL	POL	28
19	POL	86	POL	POL	POL	POL	POL	28
20	0.8	86	68.8	11.0	8.30	32.0	YES	28
21	POL	86	POL	POL	POL	POL	POL	28
22	POL	86	POL	POL	POL	POL	POL	28
23	POL	86	POL	POL	POL	POL	POL	28
24	POL	86	POL	POL	POL	POL	POL	28
25	POL	86	POL	POL	POL	POL	POL	28
26	POL	86	POL	POL	POL	POL	POL	28
27	POL	86	POL	POL	POL	POL	POL	28
28	POL	86	POL	POL	POL	POL	POL	28
29	POL	86	POL	POL	POL	POL	POL	28
30	0.7	86	60.2	10.0	8.30	32.0	YES	28
31	POL	86	POL	POL	POL	POL	POL	28

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.