

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jun-23**

System Name: **USFS Tiller Ranger Station** ID#: **41** **01092** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	POL	POL	POL	POL
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	0.08	0.23	0.09	0.09	0.25
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	0.09	0.17	POL	POL	0.23
11	POL	POL	POL	0.06	0.02	0.02	0.11
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	POL	POL	POL	POL
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	0.10	0.05	0.02	0.02	0.15
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	0.06	0.09	0.05	POL	0.11
22	POL	POL	POL	0.05	0.03	0.03	0.05
23	POL	POL	POL	0.03	0.04	POL	0.05
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	POL	0.04	POL	0.17
26	0.04	0.04	0.04	0.04	0.04	POL	0.04
27	POL	POL	POL	0.05	0.05	POL	0.14
28	POL	POL	0.19	0.06	POL	POL	0.19
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	0.18	0.02	0.02	0.02	0.18
31							

Conventional or Direct Filtration 95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE2 triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> DATE: 7/10/23 PHONE #: (541) 643-6137 CERT #: 7232	

1 including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Tiller Ranger Station				ID#: 41	01092	Month/Year: Jun-23	WTP - : A	Disinfection Giardia Log Inactiv: 0.5
---	--	--	--	---------	-------	--------------------	-----------	---------------------------------------

Date / Time	Minimum Cl2 Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	POL	86	POL	POL	POL	POL	POL	28
2	POL	86	POL	POL	POL	POL	POL	28
3	POL	86	POL	POL	POL	POL	POL	28
4	POL	86	POL	POL	POL	POL	POL	28
5	1.6	86	137.6	17.0	8.00	19.0	YES	28
6	1.2	86	103.2	17.0	7.90	19.0	YES	28
7	POL	86	POL	POL	POL	POL	POL	28
8	POL	86	POL	POL	POL	POL	POL	28
9	POL	86	POL	POL	POL	POL	POL	28
10	1.6	86	137.6	19.0	7.50	16.0	YES	28
11	1.3	86	111.8	18.0	7.80	19.0	YES	28
12	POL	86	POL	POL	POL	POL	POL	28
13	POL	86	POL	POL	POL	POL	POL	28
14	POL	86	POL	POL	POL	POL	POL	28
15	POL	86	POL	POL	POL	POL	POL	28
16	1.1	86	94.6	18.0	7.80	19.0	YES	28
17	POL	86	POL	POL	POL	POL	POL	28
18	POL	86	POL	POL	POL	POL	POL	28
19	POL	86	POL	POL	POL	POL	POL	28
20	POL	86	POL	POL	POL	POL	POL	28
21	1	86	86.0	18.0	8.20	17.4	Yes	28
22	0.7	86	60.2	17.0	7.90	16.1	Yes	28
23	0.7	86	60.2	17.0	8.10	17.3	Yes	28
24	POL	86	POL	POL	POL	POL	POL	28
25	1	86	86.0	18.0	8.00	18.0	Yes	28
26	1.2	86	103.2	20.0	7.60	14.0	Yes	28
27	1.1	86	94.6	20.0	7.90	14.0	Yes	28
28	1	86	86.0	20.0	7.90	14.0	Yes	28
29	POL	86	POL	POL	POL	POL	POL	28
30	1.1	86	94.6	20.0	7.60	14.0	Yes	28
31								

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.