

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas
 Month/Year: Feb-25

Conventional or Direct Filtration

System Name:	USFS Tiller Ranger Station		ID#: 41	01092		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	POL	POL	POL	POL
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	POL	0.03	0.04	0.03	0.04
5	0.03	POL	POL	POL	POL	POL	0.03
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	0.04	0.06	0.04	0.07
14	0.04	POL	POL	POL	POL	POL	0.04
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	POL	POL	POL	POL	POL
22	POL	POL	POL	0.06	0.05	0.04	0.06
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	POL	POL	POL	POL
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? All 4-hour turbidity readings \leq 1 NTU? All turbidity readings < IFE2 triggers	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
Yes/No Yes/No Yes/No	Yes/No	Yes/No

Notes:

PRINTED NAME: Jonathan Woody
 SIGNATURE: *Jonathan Woody*
 PHONE #: (541) 643-6137
 DATE: 3-9-25
 CERT #: 7232

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	USFS Tiller Ranger Station	ID#: 41	01092	Month/Year:	Feb-25	Disinfection Giardia Log Inactiv:	0.5
--------------	----------------------------	---------	-------	-------------	--------	-----------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
2	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
3	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
4	0.8	86	68.8	10.0	8.20	28.8	YES	28
5	0.7	86	60.2	10.0	8.30	29.6	YES	28
6	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
7	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
8	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
9	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
10	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
11	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
12	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
13	1	86	86.0	10.0	8.30	30.6	YES	28
14	0.8	86	68.8	10.0	8.30	29.9	YES	28
15	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
16	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
17	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
18	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
19	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
20	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
21	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
22	1	86	86.0	12.0	8.20	25.8	YES	28
23	0.6	86	51.6	12.0	8.20	24.6	YES	28
24	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
25	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
26	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
27	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
28	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
29		86	0.0				NO	28
30		86	0.0				NO	28
31		86	0.0				NO	28

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.