

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: MAY '25

System Name:	USFS Tiller Ranger Station			ID#: 41	01092	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	POL	POL	POL	POL
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	POL	0.04	0.04	0.04	0.07
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	0.04	0.04	0.04	0.04
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	0.04	0.03	0.07
14	0.03	POL	0.03	0.03	POL	POL	0.03
15	POL	POL	0.04	0.03	POL	POL	0.04
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	0.03	POL	POL	0.04
19	POL	POL	0.03	0.03	POL	POL	0.03
20	POL	POL	POL	0.03	POL	POL	0.04
21	POL	POL	POL	POL	POL	POL	POL
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	0.03	0.04	0.03	0.09
26	POL	POL	POL	0.04	POL	POL	0.04
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	POL	POL	POL	POL
29	POL	POL	POL	0.04	0.04	POL	0.07
30	POL	POL	0.05	0.04	0.03	POL	0.05
31	POL	POL	POL	POL	POL	POL	POL

Conventional or Direct Filtration

95% of 4-hour turbidity readings \leq 0.3 NTU?

Yes / No

All 4-hour turbidity readings \leq 1 NTU?

Yes / No

All turbidity readings < IFE2 triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point
 \geq 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

DATE: 6-9-25

PHONE #: (541) 643-6137

CERT #: 7232

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings* maximum. 2 IFE = Individ. Filter Effl. (333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	USFS Tiller Ranger Station	ID#: 41	01092	Month/Year:	May-25	Disinfection Giardia Log Inactiv:	0.5
--------------	----------------------------	---------	-------	-------------	--------	-----------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
2	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
3	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
4	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
5	0.6	86	51.6	17.0	8.40	19.1	YES	28
6	0.6	86	51.6	17.0	8.20	17.8	YES	28
7	0.9	86	77.4	16.0	8.30	20.4	YES	28
8	0.6	86	51.6	16.0	8.20	19.0	YES	28
9	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
10	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
11	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
12	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
13	1	86	86.0	16.0	8.10	19.1	YES	28
14	0.7	86	60.2	16.0	8.10	18.5	YES	28
15	0.9	86	77.4	15.0	8.20	21.0	YES	28
16	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
17	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
18	0.9	86	77.4	16.0	8.30	20.4	YES	28
19	0.8	86	68.8	16.0	8.30	20.1	YES	28
20	0.8	86	68.8	16.0	8.20	19.4	YES	28
21	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
22	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
23	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
24	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
25	0.8	86	68.8	14.0	8.30	23.0	YES	28
26	0.8	86	68.8	15.0	8.20	20.7	YES	28
27	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
28	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
29	0.8	86	68.8	16.0	8.10	18.7	YES	28
30	0.6	86	51.6	16.0	7.70	15.8	YES	28
31	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised October 2024 EM