

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County:

Douglas

Conventional or Direct Filtration

Month/Year:

Jun-25

System Name: Tiller Ranger Station

ID#: 41

01092

WTP : TP -

A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	POL	POL	POL	POL
3	POL	POL	POL	POL	0.04	0.04	0.04
4	0.04	POL	POL	POL	POL	POL	0.04
5	POL	POL	POL	POL	POL	POL	POL
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	0.06	0.04	0.04	0.06
9	0.04	POL	POL	POL	POL	POL	0.04
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	0.04	0.04	0.04	0.04	0.06
14	0.04	POL	POL	POL	POL	POL	0.04
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	0.05	0.04	0.05
18	0.04	0.03	POL	POL	POL	POL	0.04
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	POL	POL	POL	POL	POL
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	POL	0.06	0.04	0.03	0.06
24	0.04	POL	POL	POL	POL	POL	0.04
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	0.04	0.04	0.04	0.04
29	0.04	POL	POL	POL	POL	POL	0.04
30	POL	POL	POL	POL	POL	POL	POL
31							

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity readings < IFE² triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Jonathan L. Joady

SIGNATURE: [Signature]

DATE: 7-9-25

PHONE #: (541) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name: Tiller Ranger Station	ID#: 41	01092	Month/Year: 25-Jun	Disinfection <i>Giardia</i> Log Inactive:	0.5
------------------------------------	---------	-------	--------------------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
2	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
3	0.6	86	51.6	17.0	8.30	18.4	YES	28
4	0.7	86	60.2	15.0	8.40	22.1	YES	28
5	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
6	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
7	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
8	0.6	86	51.6	19.0	8.40	16.7	YES	28
9	0.6	86	51.6	19.0	8.30	16.1	YES	28
10	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
11	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
12	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
13	1.2	86	103.2	21.0	8.00	13.5	YES	28
14	0.7	86	60.2	19.0	8.10	15.2	YES	28
15	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
16	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
17	0.6	86	51.6	17.0	8.40	19.1	YES	28
18	0.6	86	51.6	16.0	8.40	20.4	YES	28
19	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
20	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
21	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
22	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
23	1.4	86	120.4	20.0	8.40	17.2	YES	28
24	0.8	86	68.8	20.0	8.30	15.4	YES	28
25	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
26	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
27	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
28	1.1	86	94.6	19.0	8.50	18.4	YES	28
29	0.7	86	60.2	21.0	8.30	14.3	YES	28
30		86						28
31		86						28

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350