

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Sep-25**

System Name: Tiller Ranger Station		ID#: 41		01092		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	POL	POL	POL	POL
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	0.04	0.04	0.04	0.04	0.04
6	0.04	POL	POL	POL	POL	POL	0.04
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	0.04	0.04	0.04	0.04
11	0.04	POL	POL	POL	POL	POL	0.04
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	POL	POL	POL	POL
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	POL	0.04	0.03	0.03	0.04
17	0.03	POL	POL	POL	POL	POL	0.03
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	POL	0.03	0.03	POL	0.04
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	0.04	0.03	POL	POL	0.04
24	POL	POL	0.04	0.03	POL	POL	0.04
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	POL	POL	POL	POL
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	0.04	0.03	0.03	POL	0.04
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity readings < IFE ² triggers	☒ Yes / No		
Notes:		PRINTED NAME: Jonathan Woody	
		SIGNATURE: John Tabachy	
		PHONE #: (541) 643-6137	
		DATE: 10-9-25	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:	Tiller Ranger Station	ID#: 41	01092	Month/Year:	25-Sep	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	-----------------------	---------	-------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
2	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
3	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
4	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
5	0.7	86	60.2	23.0	8.30	12.5	YES	28
6	0.7	86	60.2	23.0	8.20	12.0	YES	28
7	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
8	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
9	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
10	1	86	86.0	23.0	8.40	13.4	YES	28
11	0.6	86	51.6	23.0	8.40	12.8	YES	28
12	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
13	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
14	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
15	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
16	0.9	86	77.4	23.0	8.10	11.9	YES	28
17	0.7	86	60.2	23.0	8.40	13.0	YES	28
18	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
19	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
20	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
21	0.7	86	60.2	20.0	8.10	14.2	YES	28
22	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
23	0.7	86	60.2	21.0	8.30	14.3	YES	28
24	0.7	86	60.2	21.0	8.40	14.8	YES	28
25	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
26	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
27	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
28	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
29	POL	86	#VALUE!	POL	POL	#VALUE!	#VALUE!	28
30	0.7	86	60.2	21.0	8.30	14.3	YES	28
31		86						28

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350