

OHA - Drinking Water Program - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Sep-21**

System Name: USFS Tiller Ranger Station **ID#:** 41 **01092** **WTP:** TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	0.04	0.03	0.02	0.04
2	0.02	POL	POL	POL	POL	POL	0.02
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	0.03	0.02	POL	POL	0.03
5	POL	POL	POL	0.02	POL	POL	0.03
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	0.04	POL	POL	0.04
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	0.06	0.03	0.03	0.02	0.07
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	0.02	POL	POL	0.04
19	POL	POL	POL	0.03	POL	POL	0.03
20	POL	POL	POL	0.03	POL	POL	0.04
21	POL	POL	POL	POL	POL	POL	POL
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	0.05	0.03	0.03	0.05
27	0.03	POL	POL	POL	POL	POL	0.03
28	POL	POL	POL	POL	POL	POL	POL
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	POL	POL	POL	POL	POL
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)
--	---

95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No All 4-hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE2 triggers Yes / No	CT's met everyday? (see back) Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
---	--

Notes:	PRINTED NAME: Jonathan Woody SIGNATURE: <i>Jonathan Woody</i> PHONE #: (541) 643-6137 DATE: 10-3-21 CERT #: 7232
--------	--

1 Including oesometric NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individual Filter Eff. (232-661-6640(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	USFS Tiller Ranger Station	ID#: 41	01092	Month/Year:	Mar-21	Disinfection Giardia Log Inactiv:	0.5
--------------	----------------------------	---------	-------	-------------	--------	-----------------------------------	-----

Date / Time	Minimum Cl2 Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	0.7	86	60.2	21.0	8.20	16.0	YES	28
2	POL	86	POL	POL	POL	POL	POL	28
3	POL	86	POL	POL	POL	POL	POL	28
4	0.6	86	51.6	21.0	8.30	15.0	YES	28
5	0.8	86	68.8	20.0	8.20	16.0	YES	28
6	0.9	86	77.4	20.0	8.20	16.0	YES	28
7	POL	86	POL	POL	POL	POL	POL	28
8	POL	86	POL	POL	POL	POL	POL	28
9	POL	86	POL	POL	POL	POL	POL	28
10	0.8	86	68.8	19.0	8.20	21.0	YES	28
11	1.2	86	103.2	19.0	8.30	22.0	YES	28
12	1.1	86	94.6	19.0	8.30	22.0	YES	28
13	1.1	86	94.6	19.0	8.20	22.0	YES	28
14	0.7	86	60.2	19.0	8.30	21.0	YES	28
15	POL	86	POL	POL	POL	POL	POL	28
16	POL	86	POL	POL	POL	POL	POL	28
17	0.6	86	51.6	19.0	8.30	20.0	YES	28
18	0.5	86	43.0	19.0	8.30	20.0	YES	28
19	1.1	86	94.6	19.0	8.10	22.0	YES	28
20	1.1	86	94.6	19.0	8.30	22.0	YES	28
21	POL	86	POL	POL	POL	POL	POL	28
22	POL	86	POL	POL	POL	POL	POL	28
23	POL	86	POL	POL	POL	POL	POL	28
24	POL	86	POL	POL	POL	POL	POL	28
25	0.6	86	51.6	19.0	8.30	20.0	YES	28
26	0.7	86	60.2	19.0	8.20	21.0	YES	28
27	POL	86	POL	POL	POL	POL	POL	28
28	POL	86	POL	POL	POL	POL	POL	28
29	POL	86	POL	POL	POL	POL	POL	28
30	0.7	86	60.2	18.0	8.30	21.0	YES	28
31		86						28

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012