

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Douglas**  
 Month/Year: **Oct-21**

Conventional or Direct Filtration

System Name:	USFS Tiller Ranger Station		ID#: 41	01092		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	0.04	POL	POL	POL	0.04
3	POL	POL	POL	0.04	0.03	POL	0.04
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	0.04	0.03	POL	POL	0.04
6	POL	POL	0.04	0.02	POL	POL	0.04
7	POL	POL	POL	0.02	POL	POL	0.04
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	POL	POL	POL	POL
10	POL	POL	POL	POL	POL	POL	POL
11	POL	POL	POL	0.04	0.02	0.02	0.04
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	0.04	0.02	0.02	0.04
14	0.02	POL	POL	POL	POL	POL	0.02
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	POL	0.06	POL	POL	0.06
17	POL	POL	POL	0.05	0.04	POL	0.05
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	POL	POL	POL
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	0.03	0.02	0.02	0.02	0.03
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	POL	0.03	POL	POL	0.03
24	POL	POL	POL	0.04	POL	POL	0.04
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	POL	POL	POL	POL
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	POL	0.03	POL	POL	0.06
31	POL	POL	POL	POL	POL	POL	POL

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE2 triggers Yes / No		

**Notes:**

**PRINTED NAME:** Jonathan Woody

**SIGNATURE:** \_\_\_\_\_ **DATE:** \_\_\_\_\_

**PHONE #:** ( 541 ) 643-8137 **CERT #:** 7232

1 Including continuous NTU data, if available, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Inflow Filter Error. (333-061-6048(1)(a)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Tiller Ranger Station				ID#: 41	01092	Month/Year: Oct-21	WTP -: A	Disinfection Giardia Log Inactiv: 0.5
---	--	--	--	---------	-------	--------------------	----------	---------------------------------------

Date / Time	Minimum Cl2 Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	0.4	86	34.4	18.0	8.30	20.0	YES	28
2	0.6	86	51.6	18.0	8.20	20.0	YES	28
3	0.6	86	51.6	18.0	8.30	20.0	YES	28
4	POL	86	POL	POL	POL	POL	POL	28
5	1.2	86	103.2	18.0	8.20	22.0	YES	28
6	0.8	86	68.8	17.0	8.30	21.0	YES	28
7	1.2	86	103.2	17.0	8.20	22.0	YES	28
8	1.1	86	94.6	17.0	8.30	22.0	YES	28
9	1.3	86	111.8	17.0	8.20	23.0	YES	28
10	1.1	86	94.6	17.0	8.20	22.0	YES	28
11	0.7	86	60.2	17.0	8.20	21.0	YES	28
12	POL	86	POL	POL	POL	POL	POL	28
13	1.2	86	103.2	17.0	8.30	22.0	YES	28
14	POL	86	POL	POL	POL	POL	POL	28
15	POL	86	POL	POL	POL	POL	POL	28
16	1	86	86.0	17.0	8.30	22.0	YES	28
17	1.3	86	111.8	17.0	8.30	23.0	YES	28
18	POL	86	POL	POL	POL	POL	POL	28
19	POL	86	POL	POL	POL	POL	POL	28
20	POL	86	POL	POL	POL	POL	POL	28
21	0.8	86	68.8	17.0	8.30	21.0	YES	28
22	POL	86	POL	POL	POL	POL	POL	28
23	0.6	86	51.6	17.0	8.30	20.0	YES	28
24	1.3	86	111.8	15.0	8.30	24.0	YES	28
25	POL	86	POL	POL	POL	POL	POL	28
26	POL	86	POL	POL	POL	POL	POL	28
27	0.4	86	34.4	16.0	8.20	20.0	YES	28
28	POL	86	POL	POL	POL	POL	POL	28
29	POL	86	POL	POL	POL	POL	POL	28
30	0.6	86	51.6	14.0	8.20	31.0	YES	28
31	0.7	86	60.2	14.0	8.20	32.0	YES	28

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012