

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jan-22**

System Name: **USFS Tiller Ranger Station** ID#: **41 01092** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	0.04	POL	POL	0.04
2	POL	POL	POL	0.03	0.03	POL	0.04
3	POL	POL	POL	POL	POL	POL	POL
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	POL	POL	POL	POL	POL
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	0.03	POL	0.04
8	POL	POL	POL	POL	POL	POL	POL
9	POL	POL	POL	0.04	POL	POL	0.04
10	POL	POL	POL	0.06	0.04	0.03	0.07
11	POL	POL	POL	POL	POL	POL	POL
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	POL	POL	POL	POL
15	POL	POL	POL	0.04	0.03	0.03	0.04
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	POL	POL	POL	POL
19	POL	POL	POL	POL	0.03	0.03	0.05
20	0.03	POL	POL	POL	POL	POL	0.03
21	POL	POL	POL	POL	0.03	0.03	0.04
22	0.03	POL	POL	POL	POL	POL	0.03
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	POL	POL	POL	POL
27	POL	POL	POL	POL	POL	POL	POL
28	POL	POL	POL	0.05	POL	POL	0.05
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	POL	POL	POL	POL	POL
31	POL	POL	POL	POL	POL	POL	POL

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No
All turbidity readings < IFE2 triggers	<input checked="" type="radio"/> Yes / No		

Notes:

PRINTED NAME: Jonathan Woody
 SIGNATURE: *Jonathan Woody* DATE: 2-8-22
 PHONE #: (541) 643-6137 CERT #: 7232

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1))e(B&C)

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Tiller Ranger Station ID#: 41 01092 Month/Year: Jan-22 Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	86	68.8	8.0	8.50	42.0	YES	28
2	1.3	86	111.8	10.0	8.30	34.0	YES	28
3	POL	86	POL	POL	POL	POL	POL	POL
4	POL	86	POL	POL	POL	POL	POL	POL
5	POL	86	POL	POL	POL	POL	POL	POL
6	POL	86	POL	POL	POL	POL	POL	POL
7	1.2	86	103.2	10.0	8.00	28.0	YES	28
8	0.7	86	60.2	11.0	8.20	32.0	YES	28
9	0.5	86	43.2	12.0	7.70	26.0	YES	28
10	0.7	86	63.2	12.0	7.70	26.0	YES	28
11	POL	86	POL	POL	POL	POL	POL	POL
12	POL	86	POL	POL	POL	POL	POL	POL
13	POL	86	POL	POL	POL	POL	POL	POL
14	POL	86	POL	POL	POL	POL	POL	POL
15	1	86	86.0	12.0	8.20	33.0	YES	28
16	1.3	86	111.8	12.0	8.50	34.0	YES	28
17	1.4	86	120.4	12.0	8.40	34.0	YES	28
18	POL	86	POL	POL	POL	POL	POL	POL
19	1.5	86	129.0	13.0	8.30	35.0	YES	28
20	POL	86	POL	POL	POL	POL	POL	POL
21	1.4	86	120.4	12.0	8.40	34.0	YES	28
22	1.1	86	94.6	10.0	8.40	33.0	YES	28
23	1.2	86	103.2	10.0	8.40	33.0	YES	28
24	POL	86	POL	POL	POL	POL	POL	POL
25	POL	86	POL	POL	POL	POL	POL	POL
26	POL	86	POL	POL	POL	POL	POL	POL
27	POL	86	POL	POL	POL	POL	POL	POL
28	1	86	86.0	10.0	8.40	33.0	YES	28
29	0.9	86	77.4	12.0	8.40	33.0	YES	28
30	0.8	86	77.4	11.0	8.40	33.0	YES	28
31	POL	86	POL	POL	POL	POL	POL	POL

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012