

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jun-22

System Name: USFS Tiller Ranger Station ID#: 41 01092 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	POL	POL	POL	POL	POL	POL	POL
2	POL	POL	POL	0.04	0.26	0.04	0.26
3	0.02	POL	POL	POL	POL	POL	0.02
4	POL	POL	POL	POL	POL	POL	POL
5	POL	POL	POL	POL	POL	POL	POL
6	POL	POL	POL	POL	POL	POL	POL
7	POL	POL	POL	POL	POL	POL	POL
8	POL	POL	POL	0.17	POL	0.19	0.19
9	POL	POL	POL	POL	POL	POL	POL
10	POL	0.06	0.03	0.03	POL	POL	0.06
11	POL	POL	POL	POL	0.07	POL	0.07
12	POL	POL	POL	POL	POL	POL	POL
13	POL	POL	POL	POL	POL	POL	POL
14	POL	POL	POL	POL	POL	POL	POL
15	POL	POL	POL	POL	POL	POL	POL
16	POL	POL	POL	POL	POL	POL	POL
17	POL	POL	POL	POL	POL	POL	POL
18	POL	POL	POL	0.08	POL	POL	0.11
19	POL	POL	POL	0.05	POL	POL	0.11
20	POL	POL	POL	POL	POL	POL	POL
21	POL	POL	0.04	0.03	0.03	POL	0.06
22	POL	POL	POL	POL	POL	POL	POL
23	POL	POL	POL	POL	POL	POL	POL
24	POL	POL	POL	POL	POL	POL	POL
25	POL	POL	POL	POL	POL	POL	POL
26	POL	POL	POL	0.05	0.07	POL	0.07
27	POL	POL	POL	0.06	0.03	0.03	0.06
28	POL	POL	POL	POL	POL	POL	POL
29	POL	POL	POL	POL	POL	POL	POL
30	POL	POL	POL	POL	POL	POL	POL
31							

<p>Conventional or Direct Filtration</p> <p>95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All turbidity readings < IFE2 triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>		<p>Monthly Summary (Answer Yes or No)</p> <p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>	
---	--	--	--

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

PHONE #: (541) 643-6137

DATE: 7-10-22

CERT #: 7232

1 Including continuous NTU data, if applicable, for optimization reording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Tiller Ranger Station	ID#: 41	01092	Month/Year: Jun-22	Disinfection Giardia Log Inactiv: 0.5
---	---------	-------	--------------------	---------------------------------------

Date / Time	Minimum Cl2 Residual at 1st User (C) 3 [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	POL	POL	POL	POL	POL	POL	POL	28
2	0.6	86	51.6	17.0	8.00	17.0	YES	28
3	POL	POL	POL	POL	POL	POL	POL	28
4	POL	POL	POL	POL	POL	POL	POL	28
5	POL	POL	POL	POL	POL	POL	POL	28
6	POL	POL	POL	POL	POL	POL	POL	28
7	POL	POL	POL	POL	POL	POL	POL	28
8	1.2	86	103.2	17.0	7.90	19.0	YES	28
9	POL	POL	POL	POL	POL	POL	POL	28
10	0.9	86	77.4	15.0	7.90	18.0	YES	28
11	0.9	86	77.4	16.0	8.30	22.0	YES	28
12	1.2	86	103.2	17.0	8.30	22.0	YES	28
13	POL	POL	POL	POL	POL	POL	POL	28
14	0.8	86	68.8	17.0	8.30	20.0	YES	28
15	0.7	86	60.2	17.0	8.10	21.0	YES	28
16	0.5	86	43.0	18.0	8.20	20.0	YES	28
17	POL	POL	POL	POL	POL	POL	POL	28
18	0.7	86	68.8	17.0	8.20	20.0	YES	28
19	0.4	86	34.4	17.0	7.80	17.0	YES	28
20	0.6	86	51.6	16.0	7.80	17.0	YES	28
21	1.1	86	94.6	16.0	7.70	19.0	YES	28
22	POL	86	POL	POL	POL	POL	POL	28
23	POL	86	POL	POL	POL	POL	POL	28
24	POL	86	POL	POL	POL	POL	POL	28
25	1.4	86	120.4	17.0	8.40	23.0	YES	28
26	1.3	86	111.8	18.0	8.50	23.0	YES	28
27	1	86	86.0	19.0	7.90	18.0	YES	28
28	0.8	86	68.8	19.0	8.40	21.0	YES	28
29	POL	86	POL	POL	POL	POL	POL	28
30	POL	86	POL	POL	POL	POL	POL	28
31		86						28

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012