

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: **Douglas**
 Month/Year: **Mar-23**

Conventional or Direct Filtration

System Name:	USFS Tiller Ranger Station		ID#: 41	01092			WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1	POL	POL	POL	POL	POL	POL	POL	
2	POL	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	POL	POL	POL	POL	
7	POL	POL	POL	POL	POL	POL	POL	
8	POL	POL	POL	0.10	0.06	0.05	0.10	
9	POL	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	POL	POL	POL	POL	
12	POL	POL	POL	POL	POL	POL	POL	
13	POL	POL	POL	POL	POL	POL	POL	
14	POL	POL	POL	POL	POL	POL	POL	
15	POL	POL	POL	POL	POL	POL	POL	
16	POL	POL	POL	POL	POL	POL	POL	
17	POL	POL	0.05	0.05	0.05	POL	0.06	
18	POL	POL	POL	POL	POL	POL	POL	
19	POL	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	POL	POL	POL	POL	
22	POL	POL	POL	POL	POL	POL	POL	
23	POL	POL	POL	POL	POL	POL	POL	
24	POL	POL	POL	POL	POL	POL	POL	
25	POL	POL	POL	0.10	0.05	0.05	0.10	
26	0.10	POL	POL	0.05	POL	POL	0.16	
27	POL	POL	POL	POL	POL	POL	POL	
28	POL	POL	POL	POL	POL	POL	POL	
29	POL	POL	POL	POL	POL	POL	POL	
30	POL	POL	POL	POL	POL	POL	POL	
31	POL	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / No		All Cl2 residual at entry point ≥ 0.2 mg/l?
All turbidity readings < IFE2 triggers	<input checked="" type="radio"/> Yes / No		<input checked="" type="radio"/> Yes / No
Notes:		PRINTED NAME: Jonathan Woody	
		SIGNATURE: <i>Jonathan Woody</i>	
		DATE: 4/8/23	CERT #: 7232
		PHONE #: (541) 643-6137	

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-004(1)(a)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Tiller Ranger Station ID#: 41 01092 Month/Year: Mar-23 Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly Demand Flow [GPM]
1	POL	86	POL	POL	POL	POL	POL	28
2	POL	86	POL	POL	POL	POL	POL	28
3	POL	86	POL	POL	POL	POL	POL	28
4	POL	86	POL	POL	POL	POL	POL	28
5	POL	86	POL	POL	POL	POL	POL	28
6	POL	86	POL	POL	POL	POL	POL	28
7	POL	86	POL	POL	POL	POL	POL	28
8	1.4	86	120.4	10.0	8.40	34.0	Yes	28
9	1.8	86	151.2	10.0	8.30	36.0	Yes	28
10	POL	86	POL	POL	POL	POL	POL	28
11	POL	86	POL	POL	POL	POL	POL	28
12	POL	86	POL	POL	POL	POL	POL	28
13	POL	86	POL	POL	POL	POL	POL	28
14	POL	86	POL	POL	POL	POL	POL	28
15	POL	86	POL	POL	POL	POL	POL	28
16	POL	86	POL	POL	POL	POL	POL	28
17	1.7	86	142.8	12.0	7.90	30.0	YES	28
18	POL	86	POL	POL	POL	POL	POL	28
19	POL	86	POL	POL	POL	POL	POL	28
20	POL	86	POL	POL	POL	POL	POL	28
21	POL	86	POL	POL	POL	POL	POL	28
22	POL	86	POL	POL	POL	POL	POL	28
23	POL	86	POL	POL	POL	POL	POL	28
24	POL	86	POL	POL	POL	POL	POL	28
25	POL	86	POL	POL	POL	POL	POL	28
26	1.7	86	142.8	12.0	8.20	36.0	YES	28
27	1.3	86	111.8	8.0	7.80	38.0	YES	28
28	POL	86	POL	POL	POL	POL	POL	28
29	POL	86	POL	POL	POL	POL	POL	28
30	POL	86	POL	POL	POL	POL	POL	28
31	POL	86	POL	POL	POL	POL	POL	28

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012