

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jul-23**

System Name:	USFS Tiller Ranger Station		ID#: 41	01092			WTP: TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1	POL	POL	POL	POL	POL	POL	POL	
2	POL	POL	POL	POL	POL	POL	POL	
3	POL	POL	0.04	0.02	POL	POL	0.04	
4	POL	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	POL	0.03	0.02	0.05	
7	0.02	POL	POL	POL	POL	POL	0.02	
8	POL	POL	POL	POL	POL	POL	POL	
9	POL	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	0.03	0.02	0.03	0.04	
12	0.02	POL	POL	POL	POL	POL	0.02	
13	POL	POL	POL	POL	POL	POL	POL	
14	POL	POL	POL	POL	POL	POL	POL	
15	POL	POL	POL	POL	POL	POL	POL	
16	POL	POL	POL	0.03	0.04	0.04	0.05	
17	POL	POL	POL	POL	POL	POL	POL	
18	POL	POL	POL	POL	POL	POL	POL	
19	POL	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	POL	
21	POL	POL	0.05	0.05	0.05	POL	0.06	
22	POL	POL	0.07	0.05	POL	POL	0.07	
23	POL	POL	POL	POL	POL	POL	POL	
24	POL	POL	POL	POL	POL	POL	POL	
25	POL	POL	POL	POL	POL	POL	POL	
26	POL	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	POL	0.06	0.06	0.09	
28	0.06	POL	POL	POL	POL	POL	0.06	
29	POL	POL	POL	POL	POL	POL	POL	
30	POL	POL	POL	POL	POL	POL	POL	
31	POL	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE2 triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Jonathan Woody		DATE: 8/8/23
	SIGNATURE: <i>Jonathan Woody</i>		CERT #: 7232
	PHONE #: (541) 643-6137		

1. Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Tiller Ranger Station ID#: 41 01092 Month/Year: Jul-23 Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	86	POL	POL	POL	POL	POL	28
2	POL	86	POL	POL	POL	POL	POL	28
3	0.6	86	51.6	POL	POL	POL	POL	28
4	POL	86	POL	POL	POL	POL	POL	28
5	POL	86	POL	POL	POL	POL	POL	28
6	0.6	86	51.6	19.0	8.00	17.0	YES	28
7	POL	86	POL	POL	POL	POL	POL	28
8	POL	86	POL	POL	POL	POL	POL	28
9	POL	86	POL	POL	POL	POL	POL	28
10	POL	86	POL	POL	POL	POL	POL	28
11	0.9	86	77.4	22.0	8.00	14.0	YES	28
12	POL	86	POL	POL	POL	POL	POL	28
13	POL	86	POL	POL	POL	POL	POL	28
14	POL	86	POL	POL	POL	POL	POL	28
15	POL	86	POL	POL	POL	POL	POL	28
16	0.7	86	60.2	23.0	8.10	13.0	YES	28
17	POL	86	POL	POL	POL	POL	POL	28
18	POL	86	POL	POL	POL	POL	POL	28
19	POL	86	POL	POL	POL	POL	POL	28
20	POL	86	POL	POL	POL	POL	POL	28
21	0.7	86	60.2	21.0	7.90	13.0	YES	28
22	0.9	86	77.4	23.0	7.80	14.0	YES	28
23	POL	86	POL	POL	POL	POL	POL	28
24	POL	86	POL	POL	POL	POL	POL	28
25	POL	86	POL	POL	POL	POL	POL	28
26	POL	86	POL	POL	POL	POL	POL	28
27	0.9	86	77.4	23.0	7.90	11.0	YES	28
28	0.9	86	77.4	23.0	8.20	14.0	YES	28
29	POL	86	POL	POL	POL	POL	POL	28
30	POL	86	POL	POL	POL	POL	POL	28
31	POL	86	POL	POL	POL	POL	POL	28

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012