

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Douglas**  
 Month/Year: **Jun-21**

System Name: **USFS Wolf Creek Job Corps** ID#: **41** 01095 WTP: TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.00	0.00	0.00	0.01	0.01	0.01	0.01
2	0.00	0.00	0.00	0.00	0.00	0.01	0.01
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.02	0.02	0.02	0.01	0.02
5	0.00	0.00	0.00	0.02	0.02	0.02	0.02
6	0.02	0.00	0.00	0.00	0.00	0.02	0.02
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.02	0.02	0.02	0.02	0.02
9	0.00	0.00	0.00	0.02	0.02	0.00	0.02
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.00	0.00	0.00	0.02	0.02	0.02	0.02
14	0.02	0.02	0.00	0.00	0.00	0.02	0.02
15	0.00	0.00	0.02	0.02	0.02	0.00	0.02
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	0.00	0.00	0.00	0.00	0.02	0.01	0.02
18	0.01	0.02	0.00	0.00	0.00	0.02	0.02
19	0.02	0.02	0.02	0.02	0.01	0.02	0.02
20	0.00	0.00	0.00	0.00	0.00	0.02	0.02
21	0.00	0.00	0.00	0.02	0.01	0.01	0.02
22	0.02	0.00	0.00	0.00	0.00	0.01	0.02
23	0.02	0.00	0.02	0.02	0.01	0.01	0.02
24	0.02	0.02	0.00	0.00	0.00	0.02	0.02
25	0.00	0.00	0.02	0.02	0.01	0.01	0.02
26	0.00	0.00	0.02	0.02	0.01	0.02	0.02
27	0.00	0.02	0.02	0.00	0.01	0.01	0.02
28	0.00	0.00	0.02	0.02	0.02	0.02	0.02
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.02	0.02	0.02	0.02	0.02	0.00	0.02
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1.0 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's Met Everyday? (See back)	All CL2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:

PRINTED NAME: Jonathan Woody

*Jonathan Woody* 7-9-21

PHONE #: ( 541 ) 843-6137 CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Wolf Creek Job Corps					ID#: 41	01095	Month/Year: Jun-21	WTP - : A	Disinfection Giardia Log Inactiv: 0.5
--	--	--	--	--	---------	-------	--------------------	-----------	---------------------------------------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-1030	0.9	93	83.7	17.0	8.20	18.4	Yes	44
2-0700	0.9	93	83.7	19.0	8.20	16.1	Yes	44
3-0730	0.6	93	55.8	19.0	8.20	15.5	Yes	44
4-0800	0.6	93	55.8	18.0	8.20	16.6	Yes	44
5-1200	0.8	93	74.4	19.0	8.60	18.4	Yes	44
6-1200	0.8	93	74.4	19.0	8.30	16.5	Yes	44
7-0830	0.7	93	65.1	19.0	8.20	15.7	Yes	44
8-1020	0.8	93	74.4	16.0	8.20	19.4	Yes	44
9-1100	0.9	93	83.7	17.0	8.50	20.5	Yes	44
10-0800	0.9	93	83.7	17.0	8.50	20.5	Yes	44
11-0800	0.8	93	74.4	18.0	8.70	20.4	Yes	44
12-1100	0.6	93	55.8	20.0	8.30	15.1	Yes	44
13-1200	1	93	93.0	18.0	8.40	18.7	Yes	44
14-1000	0.8	93	74.4	18.0	8.10	16.4	Yes	44
15-1200	0.7	93	65.1	18.0	8.00	15.6	Yes	44
16-0900	0.6	93	55.8	18.0	8.40	17.9	Yes	44
17-0630	0.5	93	46.5	19.0	8.30	16.0	Yes	44
18-1000	1	93	93.0	19.0	8.10	15.7	Yes	44
19-1130	0.6	93	55.8	20.0	8.20	14.5	Yes	44
20-1200	0.7	93	65.1	21.0	8.40	14.8	Yes	44
21-0730	0.7	93	65.1	21.0	8.30	14.3	Yes	44
22-0730	1	93	93.0	21.0	8.40	15.3	Yes	44
23-1015	0.9	93	83.7	21.0	8.30	14.6	Yes	44
24-0800	1	93	93.0	21.0	8.10	13.7	Yes	44
25-1015	0.8	93	74.4	22.0	8.10	12.5	Yes	44
26-1100	1.3	93	120.9	23.0	8.30	13.4	Yes	44
27-1200	0.8	93	74.4	25.0	8.10	10.2	Yes	44
28-0800	0.9	93	83.7	24.0	8.60	13.4	Yes	44
29-0815	0.9	93	83.7	23.0	8.60	14.3	Yes	44
30-0915	1.2	93	111.6	23.0	8.00	11.8	Yes	44

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2014 JW