

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Douglas**  
 Month/Year: **Oct-21**

System Name: **USFS Wolf Creek Job Corps** ID#: **41** **01095** WTP: TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	0.00	0.00	0.00	0.02	0.02	0.02
2	0.00	0.00	0.02	0.02	0.00	0.00	0.02
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.03	0.02	0.02	0.00	0.03
5	0.00	0.00	0.02	0.02	0.00	0.00	0.02
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.02	0.02	0.02	0.00	0.02
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.02	0.02	0.02	0.02	0.02
12	0.00	0.00	0.00	0.00	0.00	0.02	0.02
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.00	0.00	0.02	0.02	0.02	0.02	0.02
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	0.00	0.02	0.00	0.00	0.02	0.02	0.02
18	0.00	0.00	0.00	0.00	0.00	0.02	0.02
19	0.00	0.00	0.00	0.00	0.02	0.02	0.02
20	0.02	0.02	0.00	0.00	0.00	0.02	0.02
21	0.00	0.00	0.02	0.02	0.02	0.04	0.04
22	0.11	0.18	0.33	0.03	0.02	0.03	0.33
23	0.02	0.00	0.00	0.00	0.00	0.02	0.02
24	0.00	0.00	0.00	0.02	0.02	0.00	0.02
25	0.00	0.00	0.02	0.02	0.02	0.00	0.02
28	0.00	0.00	0.00	0.02	0.02	0.02	0.02
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	0.00	0.00	0.02	0.02	0.02	0.02	0.02
29	0.02	0.00	0.00	0.02	0.02	0.02	0.02
30	0.00	0.00	0.00	0.02	0.02	0.02	0.02
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1.0 NTU?	<input checked="" type="radio"/> Yes / No	CT's met Everyday? (See back)	All Cl2 residual at entry point > 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No

Notes: 0.00= PLANT OFF

PRINTED NAME: Jonathan Woody

*Jonathan Woody*

PHONE #: ( 541 ) 643-6137

CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	USFS Wolf Creek Job Corps	ID#: 41	01096	Month/Year:	Oct-21	WTP - : Disinfection Glardie Log Inactiy:	A 0.5
--------------	---------------------------	---------	-------	-------------	--------	---	----------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1-0700	0.7	93	65.1	16.0	8.00	17.8	Yes	44
2-1330	0.6	93	55.8	16.0	8.20	19.0	Yes	44
3-0900	0.9	93	83.7	16.0	8.10	18.9	Yes	44
4-1200	0.6	93	55.8	17.0	8.10	17.1	Yes	44
5-0800	1	93	93.0	15.0	8.50	23.7	Yes	44
6-0800	0.9	93	83.7	15.0	8.20	21.0	Yes	44
7-1000	0.6	93	55.8	16.0	8.10	18.3	Yes	44
8-0730	0.6	93	55.8	15.0	8.20	20.3	Yes	44
9-1200	0.8	93	74.4	16.0	8.40	20.9	Yes	44
10-1200	0.7	93	65.1	16.0	8.30	19.9	Yes	44
11-0800	0.7	93	65.1	15.0	8.30	21.3	Yes	44
12-0800	0.8	93	74.4	15.0	8.10	20.0	Yes	44
13-0830	0.6	93	55.8	15.0	8.20	20.3	Yes	44
14-0800	0.8	93	74.4	15.0	8.10	20.0	Yes	44
15-0800	0.7	93	65.1	15.0	8.10	19.8	Yes	44
16-1100	0.7	93	65.1	15.0	8.10	19.8	Yes	44
17-1200	0.9	93	83.7	15.0	7.80	18.1	Yes	44
18-0830	1	93	93.0	14.0	8.00	21.1	Yes	44
19-0800	0.9	93	83.7	14.0	7.90	20.1	Yes	44
20-0730	0.8	93	74.4	14.0	7.90	19.9	Yes	44
21-0800	1	93	93.0	14.0	8.00	21.1	Yes	44
22-0800	0.9	93	83.7	14.0	8.20	22.4	Yes	44
23-1100	0.6	93	55.8	15.0	7.90	18.2	Yes	44
24-1200	1.7	93	158.1	15.0	7.80	19.8	Yes	44
25-1030	1.2	93	111.6	14.0	7.90	20.8	Yes	44
26-1400	1	93	93.0	14.0	7.90	20.3	Yes	44
27-0910	0.5	93	46.5	15.0	7.80	17.3	Yes	44
28-1430	1.3	93	120.9	14.0	7.70	19.5	Yes	44
29-0800	0.9	93	83.7	14.0	7.80	19.4	Yes	44
30-1100	0.7	93	65.1	13.0	7.90	21.0	Yes	44
31-1200	1.1	93	102.3	14.0	8.00	21.3	Yes	44

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2014 JW