

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **Feb-22**

System Name: **USFS Wolf Creek Job Corps** ID#: **41** **01095** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.00	0.00	0.00	0.00	0.02	0.02	0.02
2	0.00	0.00	0.00	0.00	0.00	0.02	0.02
3	0.00	0.02	0.02	0.00	0.00	0.00	0.02
4	0.00	0.00	0.02	0.00	0.00	0.00	0.02
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.02	0.01	0.02	0.02
7	0.02	0.00	0.02	0.00	0.00	0.02	0.02
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.02	0.02
10	0.02	0.02	0.00	0.00	0.00	0.02	0.02
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.02	0.02	0.02	0.00	0.00	0.02	0.02
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.00	0.02	0.00	0.02	0.02	0.02	0.02
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00	0.02	0.02	0.02
20	0.02	0.00	0.00	0.00	0.00	0.02	0.02
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.00	0.00	0.02	0.01	0.01	0.02	0.02
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.02	0.01	0.02	0.02	0.02
26	0.00	0.00	0.00	0.00	0.00	0.02	0.02
27	0.00	0.00	0.00	0.00	0.02	0.00	0.02
28	0.00	0.00	0.00	0.02	0.02	0.02	0.02
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1.0 NTU? All daily turbidity readings ≤ 5 NTU?	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: *0.00 = Plant off Line*

PRINTED NAME: **Jonathan Woody**
 SIGNATURE: *Jonathan Woody* DATE: **3/9/2022**
 PHONE #: (541) 643-6137 CERT #: **7232**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Wolf Creek Job Corps						ID#: 41	01095	Month/Year: February-22	WTP - : A
								Disinfection <i>Giardia</i> Log Inactiv: 0.5	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1-0800	1	93	93.0	11.0	7.60	22.3	Yes	44
2-0800	1.1	93	102.3	10.0	7.50	23.2	Yes	44
3-0800	1.2	93	111.6	10.0	7.50	23.5	Yes	44
4-0830	1.4	93	130.2	9.0	7.50	25.7	Yes	44
5-1200	1.3	93	120.9	10.0	7.50	23.8	Yes	44
6-1200	0.9	93	83.7	11.0	7.50	21.3	Yes	44
7-0830	1.1	93	102.3	10.0	7.50	23.2	Yes	44
8-0800	1	93	93.0	11.0	7.60	22.3	Yes	44
9-0800	0.9	93	83.7	11.0	7.50	21.3	Yes	44
10-0730	0.9	93	83.7	12.0	7.40	19.2	Yes	44
11-0830	1.4	93	130.2	9.0	7.60	26.7	Yes	44
12-1200	1	93	93.0	11.0	7.90	24.8	Yes	44
13-1200	1.5	93	139.5	11.0	7.80	25.3	Yes	44
14-0800	1.3	93	120.9	11.0	7.70	23.9	Yes	44
15-0830	1	93	93.0	12.0	7.70	21.6	Yes	44
16-0800	0.2	93	18.6	12.0	7.60	19.1	Yes	44
17-0730	1.1	93	102.3	12.0	7.70	21.9	Yes	44
18-0630	0.9	93	83.7	11.0	7.60	22.0	Yes	44
19-1100	1	93	93.0	12.0	7.90	23.2	Yes	44
20-1200	1.2	93	111.6	11.0	7.80	24.5	Yes	44
21-0800	0.9	93	83.7	12.0	7.70	21.4	Yes	44
22-0830	1.3	93	120.9	10.0	7.80	26.5	Yes	44
23-0800	1.3	93	120.9	10.0	7.90	27.4	Yes	44
24-0800	1	93	93.0	10.0	7.70	24.7	Yes	44
25-0830	1	93	93.0	10.0	7.80	25.6	Yes	44
26-1200	1.4	93	130.2	11.0	7.40	21.7	Yes	44
27-1200	1	93	93.0	13.0	7.70	20.2	Yes	44
28-		93						44
29-		93						44
30-		93						44
31-		93						44

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2014 JW