

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **Mar-22**

System Name: **USFS Wolf Creek Job Corps** ID#: **41** 01095 WTP: TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.02	0.02	0.02	0.00	0.00	0.00	0.02
4	0.00	0.00	0.02	0.00	0.00	0.00	0.02
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.02	0.01	0.00	0.02	0.02	0.02
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.02	0.02	0.02	0.00	0.00	0.02
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.02	0.01	0.02	0.00	0.02
12							POL
13							POL
14	0.00	0.00	0.02	0.02	0.02	0.02	0.02
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.02	0.02	0.02	0.02
19	0.02	0.02	0.00	0.00	0.00	0.02	0.02
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.02	0.02	0.02	0.02	0.02
25	0.02	0.00	0.00	0.00	0.00	0.02	0.02
26	0.00	0.00	0.00	0.00	0.00	0.00	0.00
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.00	0.00	0.02	0.02	0.02	0.02	0.02
30	0.02	0.00	0.00	0.00	0.00	0.02	0.02
31	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1.0 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No		

Notes: 0.00 =plant off line (pol). Power Outage 12th,13th

PRINTED NAME: Jonathan Woody
 SIGNATURE: *Jonathan Woody* DATE: 4-8-22
 PHONE #: (541) 643-6137 CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	A
Disinfection <i>Giardia</i> Log Inactlv:	0.5

System Name: USFS Wolf Creek Job Corps ID#: 41 01095 Month/Year: Mar-22

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-0830	1	93	93.0	12.0	7.80	22.4	yes	44
2-1100	1	93	93.0	13.0	7.70	20.2	yes	44
3-0830	1.5	93	139.5	10.0	7.50	24.3	yes	44
4-0830	1.2	93	111.6	10.0	7.60	24.4	yes	44
5-1200	1	93	93.0	11.0	7.60	22.3	yes	44
6-1200	0.9	93	83.7	11.0	7.50	21.3	yes	44
7-1000	1.4	93	130.2	10.0	7.00	20.2	yes	44
8-1200	1	93	93.0	11.0	7.40	20.8	yes	44
9-0950	2.1	93	195.3	8.0	7.20	26.8	yes	44
10-0845	1.2	93	111.6	9.0	7.50	25.1	yes	44
11-1140	1.2	93	111.6	10.0	7.60	24.4	yes	44
12-1200	1.2	93	111.6	12.0	7.60	21.3	yes	44
13-1100	1	93	93.0	12.0	7.20	18.2	yes	44
14-1050	1.5	93	139.5	9.0	7.40	25.1	yes	44
15-0940	1.2	93	111.6	10.0	7.40	22.7	yes	44
16-0750	1	93	93.0	11.0	7.40	20.8	yes	44
17-0830	0.9	93	83.7	11.0	7.50	21.3	yes	44
18-1330	0.8	93	74.4	10.0	7.60	23.3	yes	44
19-1130	1.2	93	111.6	12.0	7.10	17.9	yes	44
20-1200	1	93	93.0	12.0	7.20	18.2	yes	44
21-0800	1	93	93.0	12.0	7.40	19.5	yes	44
22-1030	0.9	93	83.7	13.0	7.10	16.0	yes	44
23-1200	0.8	93	74.4	12.0	7.20	17.8	yes	44
24-0800	0.6	93	55.8	11.0	7.50	20.6	yes	44
25-0725	1.3	93	120.9	11.0	7.50	22.3	yes	44
26-0930	1	93	93.0	12.0	7.10	17.6	yes	44
27-1200	0.7	93	65.1	13.0	7.40	17.4	yes	44
28-0800	0.7	93	65.1	12.0	7.40	18.8	yes	44
29-0730	0.8	93	74.4	11.0	7.50	21.0	yes	44
30-0845	1.3	93	120.9	11.0	7.70	23.9	yes	44
31-1230	POL	93	POL	POL	POL	POL	POL	44

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.