

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **Apr-22**

System Name: **USFS Wolf Creek Job Corps** ID#: **41** **01095** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.02	0.02	0.00	0.02	0.02	0.02	0.02
3	0.02	0.00	0.00	0.00	0.00	0.02	0.02
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.02	0.02	0.02	0.02	0.02
6	0.02	0.00	0.00	0.00	0.00	0.02	0.02
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	0.00	0.00	0.02	0.02
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.02	0.02	0.02	0.02	0.02	0.00	0.02
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.00	0.00	0.02	0.02	0.02	0.02	0.02
15	0.02	0.02	0.00	0.00	0.00	0.02	0.02
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	0.00	0.00	0.00	0.02	0.02	0.02	0.02
18	0.00	0.00	0.02	0.02	0.02	0.02	0.02
19	0.02	0.00	0.00	0.00	0.00	0.02	0.02
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	0.00	0.00	0.02	0.00	0.00	0.00	0.02
22	0.00	0.00	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.02	0.02	0.02	0.02	0.00	0.00	0.02
27	0.00	0.00	0.02	0.02	0.02	0.00	0.02
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1.0 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No		

Notes: **0.00 = Plant off line**

PRINTED NAME: Jonathan Woody
 SIGNATURE: *Jonathan Woody* DATE: **5/10/22**
 PHONE #: (541) 643-6137 CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-C040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	USFS Wolf Creek Job Corps	ID#: 41	01095	Month/Year:	Apr-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	---------------------------	---------	-------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-0730	0.9	93	83.7	12.0	7.50	19.9	yes	44
2-0845	1.38	93	128.3	10.5	7.40	22.4	yes	44
3-0830	1.3	93	120.9	11.0	7.40	21.5	yes	44
4-0945	1.1	93	102.3	12.0	7.50	20.4	yes	44
5-0850	1.1	93	102.3	11.0	7.50	21.8	yes	44
6-0850	1.2	93	111.6	10.0	7.50	23.5	yes	44
7-0915	1	93	93.0	12.0	7.40	19.5	yes	44
8-0905	0.8	93	74.4	11.0	7.50	21.0	yes	44
9-0900	1.2	93	111.6	11.0	7.50	22.0	yes	44
10-0900	1.1	93	102.3	12.0	7.30	19.0	yes	44
11-0915	1.4	93	130.2	9.0	7.20	23.1	yes	44
12-0805	0.7	93	65.1	11.0	7.40	20.1	yes	44
13-0820	0.5	93	46.5	12.0	7.00	16.1	yes	44
14-0900	0.6	93	55.8	11.0	7.20	18.5	yes	44
15-0930	1.4	93	130.2	10.0	7.30	22.4	yes	44
16-0845	1	93	93.0	11.0	7.30	20.1	yes	44
17-1200	0.8	93	74.4	13.0	7.40	17.6	yes	44
18-0830	1.4	93	130.2	11.0	7.40	21.7	yes	44
19-0910	1.2	93	111.6	11.0	7.50	22.0	yes	44
20-1011	0.9	93	83.7	12.0	7.40	19.2	yes	44
21-0915	0.9	93	83.7	13.0	7.40	17.8	yes	44
22-1000	0.6	93	55.8	12.0	7.20	17.4	yes	44
23-0900	1.6	93	148.8	10.0	7.60	25.5	yes	44
24-0915	1.3	93	120.9	12.0	7.40	20.1	yes	44
25-0745	1.1	93	102.3	12.0	7.50	20.4	yes	44
26-0730	1.5	93	139.5	10.0	7.50	24.3	yes	44
27-0930	1.2	93	111.6	11.0	7.50	22.0	yes	44
28-1000	1.1	93	102.3	13.0	7.60	19.7	yes	44
29-0900	1.1	93	102.3	13.0	7.40	18.3	yes	44
30-0830	1	93	93.0	14.0	7.80	19.6	yes	44

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.