

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Douglas**  
 Month/Year: **May-22**

System Name:	USFS Wolf Creek Job Corps		ID#: 41	01095		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.00	0.00	0.00	0.00	0.00	0.02	0.02
2	0.02	0.02	0.02	0.02	0.00	0.02	0.02
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.02	0.02	0.02	0.02	0.00	0.00	0.02
8	0.00	0.00	0.00	0.01	0.02	0.00	0.02
9	0.00	0.00	0.02	0.02	0.00	0.00	0.02
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.00	0.00	0.02	0.02	0.02	0.02	0.02
15	0.02	0.00	0.00	0.00	0.00	0.02	0.02
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00	0.00	0.02	0.02
20	0.02	0.00	0.02	0.02	0.02	0.02	0.02
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.00	0.00	0.02	0.02	0.02	0.00	0.02
27	0.00	0.00	0.02	0.02	0.02	0.00	0.02
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.00	0.00	0.02	0.00	0.00	0.00	0.02
30	0.00	0.00	0.00	0.02	0.02	0.00	0.02
31	0.00	0.00	0.00	0.00	0.00	0.00	0.00

**Slow Sand/Membrane/DE Filtration/Unfiltered**

95% of daily turbidity readings ≤ 1.0 NTU?  Yes /  No

All daily turbidity readings ≤ 5 NTU?  Yes /  No

**Monthly Summary (Answer Yes or No)**

CT's met everyday? (see back)  Yes /  No

All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes /  No

**Notes:** 5/28/2022 Plant Off Line (power outage)

**PRINTED NAME:** Jonathan Woody  
**SIGNATURE:** *Jonathan Woody*  
**PHONE #:** ( 541 ) 643-6137  
**DATE:** 6/10/22  
**CERT #:** 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-081-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Wolf Creek Job Corps						ID#: 41	01095	Month/Year: May-22	WTP - : A	Disinfection Giardia Log Inactiv: 0.5
--	--	--	--	--	--	---------	-------	--------------------	-----------	---------------------------------------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1-1200	0.7	93	65.1	14.0	7.50	16.9	YES	44
2-0825	1.6	93	148.8	10.0	7.20	22.1	YES	44
3-1400	0.9	93	83.7	14.0	7.30	16.1	YES	44
4-0730	0.8	93	74.4	13.0	7.30	17.0	YES	44
5-0850	0.7	93	65.1	14.0	7.40	16.3	YES	44
6-0905	0.5	93	46.5	14.0	7.20	14.8	YES	44
7-0900	1.4	93	130.2	11.0	7.30	21.0	YES	44
8-1200	1.7	93	158.1	10.0	7.50	24.9	YES	44
9-1050	1	93	93.0	12.0	7.30	18.8	YES	44
10-0830	1.2	93	111.6	12.0	7.30	19.2	YES	44
11-0850	0.9	93	83.7	14.0	7.30	16.1	YES	44
12-0730	0.8	93	74.4	14.0	7.30	15.9	YES	44
13-0820	0.6	93	55.8	14.0	7.40	16.1	YES	44
14-0845	0.6	93	55.8	15.0	7.30	14.5	YES	44
15-1200	1.2	93	111.6	15.0	7.50	16.8	YES	44
16-1000	1	93	93.0	14.0	7.20	15.7	YES	44
17-0930	0.8	93	74.4	14.0	7.20	15.3	YES	44
18-0730	0.7	93	65.1	14.0	7.20	15.2	YES	44
19-1230	0.7	93	65.1	14.0	7.40	16.3	YES	44
20-0930	1.3	93	120.9	12.0	7.40	20.1	YES	44
21-0845	1.2	93	111.6	13.0	7.50	19.2	YES	44
22-0845	1.1	93	102.3	14.0	7.60	18.4	YES	44
23-0830	1.1	93	102.3	14.0	7.40	17.1	YES	44
24-0520	0.9	93	83.7	14.0	7.20	15.5	YES	44
25-0730	0.7	93	65.1	15.0	7.20	14.2	YES	44
26-1130	0.8	93	74.4	15.0	7.60	16.6	YES	44
27-1310	1.3	93	120.9	15.0	7.40	16.3	YES	44
28-0845	0.6	93	55.8	15.0	7.5	15.7	YES	44
29-0930	1.1	93	102.3	15.0	7.50	16.6	YES	44
30-0845	1	93	93.0	15.0	7.30	15.2	YES	44
31-0845	1.9	93	176.7	14.0	7.40	18.7	YES	44

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2014 JW