

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **Jun-22**

System Name:	USFS Wolf Creek Job Corps		ID#: 41	01095		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	pol	pol	pol	pol	pol	pol	pol
5	0.00	0.00	0.00	0.02	0.00	0.00	0.02
6	0.00	0.00	0.02	0.02	0.02	0.02	0.02
7	0.02	0.00	0.00	0.00	0.00	0.02	0.02
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.02	0.02	0.02	0.02
12	0.00	0.00	0.00	0.02	0.02	0.02	0.02
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.00	0.00	0.02	0.02	0.00	0.00	0.02
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.00	0.00	0.02	0.02	0.02	0.00	0.02
17	0.00	0.00	0.02	0.02	0.00	0.00	0.02
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00	0.00	0.00	0.00
20	0.00	0.00	0.02	0.02	0.00	0.00	0.02
21	0.00	0.00	0.00	0.03	0.02	0.00	0.03
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.00	0.00	0.02	0.02	0.02	0.00	0.02
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1.0 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No		

Notes: <i>pol / 0.00 = Plant off Line</i>	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>John Woody</i>	DATE: <i>7/10/22</i>
	PHONE #: (541) 643-6137	CERT #: 7232

¹Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Wolf Creek Job Corps						ID#: 41	01095	Month/Year: Jun-22	WTP - : A
Disinfection <i>Giardia</i> Log Inactiv:								0.5	

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-0845	1.6	93	148.8	15.0	7.50	17.6	yes	44
2-0755	1.4	93	130.2	15.0	7.30	15.9	yes	44
3-0745	1.2	93	111.6	16.0	7.40	15.1	yes	44
4-0730	0.7	93	65.1	15.0	7.50	15.8	yes	44
5-0730	0.8	93	74.4	15.0	7.70	17.3	yes	44
6-0840	1	93	93.0	15.0	7.20	14.7	yes	44
7-0545	1.2	93	111.6	14.0	7.40	17.3	yes	44
8-0550	0.8	93	74.4	16.0	7.20	13.4	yes	44
9-0620	0.6	93	55.8	16.0	7.20	13.1	yes	44
10-0550	0.5	93	46.5	16.0	7.20	13.0	yes	44
11-1100	1.2	93	111.6	17.0	7.20	13.1	yes	44
12-1200	1	93	93.0	14.0	7.50	17.5	yes	44
13-0845	pol	93	#VALUE!	pol	pol	#VALUE!	pol	44
14-1100	1.7	93	158.1	13.0	7.70	21.8	yes	44
15-0730	1.2	93	111.6	15.0	7.20	15.0	yes	44
16-0745	0.9	93	83.7	16.0	7.70	16.3	yes	44
17-0745	1.4	93	130.2	15.0	7.50	17.2	yes	44
18-0730	0.9	93	83.7	15.0	7.60	16.8	yes	44
19-1200	1.2	93	111.6	16.0	7.70	16.9	yes	44
20-0745	0.9	93	83.7	17.0	7.70	15.3	yes	44
21-0745	1.5	93	139.5	16.0	7.40	15.6	yes	44
22-0745	1.4	93	130.2	16.0	7.40	15.5	yes	44
23-0950	1.1	93	102.3	16.0	7.30	14.4	yes	44
24-0700	0.9	93	83.7	16.0	7.40	14.6	yes	44
25-0800	0.7	93	65.1	18.0	7.20	11.6	yes	44
26-0815	0.8	93	74.4	17.0	7.40	13.5	yes	44
27-0800	1.4	93	130.2	19.0	7.50	13.1	yes	44
28-0800	1.1	93	102.3	19.0	7.70	13.7	yes	44
29-0910	0.9	93	83.7	19.0	7.40	11.9	yes	44
30-1340	0.8	93	74.4	18.0	7.40	12.6	yes	44

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.