

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Douglas**  
 Month/Year: **Nov-22**  
 WTP : TP - **A**

System Name: **USFS Wolf Creek Job Corps** ID#: **41** **01095**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	0.00	0.00	0.00	0.00	0.00	0.02
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.02	0.02	0.02	0.00	0.02
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.02	0.02	0.00	0.00	0.00	0.00	0.02
7	0.02	0.00	0.00	0.00	0.00	0.00	0.02
8	0.03	0.02	0.02	0.02	0.02	0.02	0.03
9	0.02	0.02	0.02	0.02	0.00	0.00	0.02
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.02	0.02	0.02	0.00	0.02
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.02	0.01	0.02	0.01	0.00	0.00	0.02
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.00	0.02	0.02	0.02	0.02	0.02	0.02
17	0.00	0.00	0.00	0.00	0.00	0.02	0.02
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.02	0.02	0.02	0.02
20	0.00	0.02	0.02	0.00	0.00	0.00	0.02
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.02	0.02	0.02	0.00	0.00	0.00	0.02
23	0.02	0.02	0.02	0.02	0.02	0.00	0.02
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.00	0.00	0.00	0.00	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.02	0.02	0.02	0.00	0.00	0.00	0.02
30	POL	POL	POL	POL	POL	POL	POL
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1.0 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

**Notes:**

**PRINTED NAME: Jonathan Woody**

**SIGNATURE:** *Jonathan Woody*

**PHONE #: ( 541 ) 643-6137**

**DATE: 12-8-22**

**CERT #: 7232**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	USFS Wolf Creek Job Corps	ID#: 41	01095	Month/Year:	Nov-22	WTP - :	A
						Disinfection <i>Giardia</i> Log Inactiv:	0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-0800	1.4	93	130.2	16.0	7.60	16.7	Yes	44
2-0800	1.2	93	111.6	16.0	7.60	16.3	Yes	44
3-1200	0.9	93	83.7	15.0	7.80	18.1	Yes	44
4-0800	0.7	93	65.1	16.0	7.90	17.2	Yes	44
5-0800	1	93	93.0	13.0	7.40	18.0	Yes	44
6-0800	0.5	93	46.5	16.0	7.30	13.4	Yes	44
7-0750	0.5	93	46.5	15.0	7.30	14.4	Yes	44
8-1015	1.4	93	130.2	13.0	7.30	18.2	yes	44
9-0750	1.6	93	148.8	13.0	7.40	19.3	Yes	44
10-0750	0.9	93	83.7	12.0	7.30	18.6	Yes	44
11-0730	0.5	93	46.5	13.0	7.40	17.1	Yes	44
12-0750	1	93	93.0	11.0	7.30	20.1	Yes	44
13-0750	0.7	93	65.1	11.0	7.30	19.4	Yes	44
14-0800	1.5	93	139.5	12.0	7.30	19.9	Yes	44
15-0800	1.1	93	102.3	12.0	7.30	19.0	Yes	44
16-0755	0.9	93	83.7	12.0	7.30	18.6	Yes	44
17-0855	1.4	93	130.2	8.0	7.60	28.5	Yes	44
18-0920	1	93	93.0	12.0	7.20	18.2	Yes	44
19-0800	0.8	93	74.4	12.0	7.20	17.8	Yes	44
20-0900	1.3	93	120.9	8.0	7.30	25.3	Yes	44
21-0800	1.2	93	111.6	10.0	7.40	22.7	Yes	44
22-0800	0.7	93	65.1	10.0	7.50	22.2	Yes	44
23-0750	1.1	93	102.3	9.0	7.70	26.7	Yes	44
24-1000	1.3	93	120.9	10.0	7.70	25.5	Yes	44
25-0830	1.1	93	102.3	11.0	7.80	24.2	Yes	44
26-0800	0.7	93	65.1	12.0	7.50	19.5	Yes	44
27-0800	1.2	93	111.6	9.0	7.80	28.0	Yes	44
28-0800	0.9	93	83.7	10.0	7.70	24.4	Yes	44
29-0800	0.5	93	46.5	11.0	7.40	19.6	Yes	44
30-0800	0.5	93	46.5	11.0	7.50	20.3	Yes	44
31-								44

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.