

**OHA - Drinking Water Program -Turbidity Monitoring Report Form**  
**Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Douglas**  
 Month/Year: **Mar-23**  
 WTP: TP - **A**

System Name:	USFS Wolf Creek Job Corps		ID#: 41	01095		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	0.02	0.02	0.02	0.02	0.00	0.00	0.02
2	0.02	0.02	0.02	0.02	0.00	0.00	0.02
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.02	0.02	0.02	0.00	0.02
6	0.02	0.02	0.02	0.02	0.00	0.00	0.02
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.02	0.02	0.01	0.01	0.00	0.02
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00	0.02	0.02	0.02
12	0.02	0.02	0.02	0.02	0.00	0.02	0.02
13	0.03	0.04	0.00	0.00	0.00	0.00	0.04
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	0.02	0.02	0.02	0.01	0.02	0.02	0.02
16	0.02	0.01	0.00	0.00	0.00	0.00	0.02
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.02	0.02	0.02	0.02	0.02	0.00	0.02
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.02	0.02	0.02	0.02	0.02	0.00	0.02
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.02	0.02	0.00	0.00	0.00	0.00	0.02
26	0.02	0.02	0.02	0.02	0.02	0.00	0.02
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.02	0.02	0.02	0.02	0.02	0.00	0.02
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
31	0.00	0.00	0.00	0.00	0.00	0.00	0.00

**Slow Sand/Membrane/DE Filtration/Unfiltered**

95% of daily turbidity readings ≤ 1.0 NTU?  Yes /  No

All daily turbidity readings ≤ 5 NTU?  Yes /  No

**Monthly Summary (Answer Yes or No)**

CT's met everyday? (see back)  Yes /  No

All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes /  No

Notes: 0.00= Plant Offline

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody* DATE: 4-8-23

PHONE #: ( 541 ) 643-6137 CERT #: 7232

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Wolf Creek Job Corps ID#: 41 01095 Month/Year: Mar-23

Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1-0800	0.9	93	83.7	8.0	7.60	26.9	Yes	44
2-0840	1.1	93	102.3	8.0	7.60	27.5	Yes	44
3-		93						44
4-		93						44
5-0800	0.9	93	83.7	10.0	7.30	21.2	Yes	44
6-0750	1.2	93	111.6	7.0	7.70	30.9	Yes	44
7-0750	1.1	93	102.3	8.0	7.60	27.5	Yes	44
8-0800	0.9	93	83.7	9.0	7.60	25.2	Yes	44
9-		93						44
10-		93						44
11-0820	0.8	93	74.4	9.0	7.50	24.0	Yes	44
12-0820	1.1	93	102.3	8.0	7.50	26.6	Yes	44
13-0750	1	93	93.0	8.0	7.60	27.2	Yes	44
14-		93						44
15-0800	0.6	93	55.8	10.0	7.40	21.2	Yes	44
16-0920	1.2	93	111.6	8.0	7.70	28.9	Yes	44
17-		93						44
18-		93						44
19-0800	0.8	93	74.4	10.0	7.40	21.7	Yes	44
20-		93					Yes	44
21-		93					Yes	44
22-0930	0.8	93	74.4	10.0	7.40	21.7	Yes	44
23-		93						44
24-		93						44
25-0815	0.8	93	74.4	9.0	7.20	21.6	Yes	44
26-0810	1.2	93	111.6	9.0	7.30	23.4	Yes	44
27-		93						44
28-		93						44
29-0800	0.8	93	74.4	9.0	7.40	23.2	Yes	44
30-		93						44
31-		93						44

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.