

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **Apr-23**

System Name: USFS Wolf Creek Job Corps ID#: 41 01095 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.00	0.02	0.00	0.00	0.00	0.00	0.02
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.02	0.00	0.00	0.00	0.00	0.02	0.02
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.02	0.02	0.02	0.02
8	0.02	0.02	0.00	0.00	0.00	0.02	0.02
9	0.02	0.02	0.02	0.02	0.00	0.00	0.02
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12	0.02	0.02	0.02	0.02	0.02	0.00	0.02
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.00	0.00	0.00	0.00	0.00	0.02	0.02
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.02	0.00	0.00	0.00	0.00	0.02	0.02
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.02	0.02	0.02	0.02	0.02	0.02
24	0.02	0.02	0.00	0.00	0.00	0.02	0.02
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.00	0.00	0.00	0.00	0.00	0.02	0.02
28	0.02	0.02	0.02	0.02	0.00	0.00	0.02
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1.0 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No

Notes:	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>Jonathan Woody</i>	DATE: 5/9/23
	PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: USFS Wolf Creek Job Corps ID#: 41 01095 Month/Year: Apr-23						WTP - : A	Disinfection <i>Giardia</i> Log Inactiv: 0.5
---	--	--	--	--	--	-----------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1-0845	0.8	93	74.4	10.0	7.30	20.9	Yes	44
2-		93					POL	44
3-0750	0.5	93	46.5	9.0	7.50	23.2	Yes	44
4-0800	1.4	93	130.2	7.0	7.30	27.4	Yes	44
5-		93					POL	44
6-		93					POL	44
7-0900	0.9	93	83.7	12.0	7.20	18.0	Yes	44
8-0800	1.2	93	111.6	8.0	7.30	25.0	Yes	44
9-0750	0.8	93	74.4	9.0	7.50	24.0	Yes	44
10-		93					POL	44
11-		93					POL	44
12-0815	0.8	93	74.4	11.0	7.30	19.6	Yes	44
13-		93					POL	44
14-		93					POL	44
15-		93					POL	44
16-0750	0.9	93	83.7	12.0	7.30	18.6	Yes	44
17-0750	1.3	93	120.9	8.0	7.50	27.2	Yes	44
18-		93					POL	44
19-0750	0.8	93	74.4	11.0	7.20	19.0	Yes	44
20-1435	1.5	93	139.5	9.0	7.50	26.0	Yes	44
21-		93					POL	44
22-		93					POL	44
23-1330	1.4	93	130.2	12.0	7.70	22.6	Yes	44
24-0800	1.5	93	139.5	9.0	7.30	24.2	Yes	44
25-		93					POL	44
26-0800	1.3	93	120.9	10.0	7.50	23.8	Yes	44
27-0750	1.4	93	130.2	10.0	7.30	22.4	Yes	44
28-0750	0.8	93	74.4	11.0	7.30	19.6	Yes	44
29-		93					POL	44
30-		93					POL	44
31-		93						44

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.