

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **Jun-23**

System Name:	USFS Wolf Creek Job Corps		ID#: 41	01095		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.00	0.00	0.00	0.02	0.02	0.02	0.02
2	0.02	0.02	0.02	0.00	0.00	0.02	0.02
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.02	0.02	0.02	0.02
5	0.02	0.02	0.01	0.02	0.00	0.02	0.02
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.02	0.02	0.02	0.02	0.00	0.00	0.02
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02
10	0.00	0.00	0.00	0.00	0.02	0.00	0.00
11	0.02	0.02	0.02	0.02	0.02	0.00	0.02
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	0.02	0.00	0.00	0.00	0.00	0.02	0.02
16	0.02	0.02	0.02	0.02	0.00	0.00	0.02
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00	0.02	0.02	0.02
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	0.00	0.00	0.02	0.02	0.02	0.00	0.02
22	0.02	0.02	0.02	0.02	0.02	0.00	0.02
23	0.00	0.00	0.02	0.00	0.00	0.00	0.02
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.02	0.02	0.00	0.00	0.02
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.00	0.00	0.00	0.02	0.00	0.00	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.00	0.00	0.02	0.00	0.00	0.00	0.02
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1.0 NTU? All daily turbidity readings ≤ 5 NTU?	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: **Jonathan Woody**

SIGNATURE: *Jonathan Woody*

PHONE #: (541) 643-6137

DATE: **7-10-23**

CERT #: **7232**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effi. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	USFS Wolf Creek Job Corps	ID#: 41	01095	Month/Year:	Jun-23	WTP - :	A
						Disinfection <i>Giardia</i> Log Inactiv:	0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-1100	0.9	93	83.7	17.0	7.00	11.8	Yes	44
2-0750	1.4	93	130.2	13.0	7.10	16.9	Yes	44
3-		93						44
4-1200	1	93	93.0	15.0	7.10	14.1	Yes	44
5-0750	1.4	93	130.2	15.0	7.10	14.8	Yes	44
6-		93						44
7-		93						44
8-0800	0.8	93	74.4	18.0	7.20	11.7	Yes	44
9-0800	1.2	93	111.6	18.0	7.30	12.7	Yes	44
10-		93						44
11-0900	1	93	93.0	17.0	7.20	12.8	Yes	44
12-		93						44
13-		93						44
14-0750	1.1	93	102.3	17.0	7.00	12.0	Yes	44
15-0750	1.4	93	130.2	15.0	7.00	14.3	Yes	44
16-0800	1.1	93	102.3	16.0	7.10	13.4	Yes	44
17-		93						44
18-1030	0.8	93	74.4	17.0	7.40	13.5	Yes	44
19-0750	1.3	93	120.9	15.0	7.10	14.6	Yes	44
20-		93						44
21-0850	0.8	93	74.4	17.0	7.50	14.0	Yes	44
22-0840	1.1	93	102.3	17.0	7.00	12.0	Yes	44
23-0800	1.1	93	102.3	18.0	7.20	12.1	Yes	44
24-		93						44
25-1420	1	93	93.0	18.0	7.00	11.1	Yes	44
26-0750	1	93	93.0	19.0	7.30	11.6	Yes	44
27-0750	1.4	93	130.2	17.0	7.10	12.9	Yes	44
28-0820	1	93	93.0	18.0	7.00	11.1	Yes	44
29-		93						44
30-0745	0.9	93	83.7	19.0	6.90	9.9	Yes	44
31-		93						44

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.