

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Slow Sand,Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **Aug-23**

System Name: **USFS Wolf Creek Job Corps** ID#: **41** **01095** WTP : TP - **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.02	0.02	0.02	0.02	0.02	0.00	0.02
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.02	0.02	0.02	0.00	0.00	0.00	0.02
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.02	0.02	0.00	0.02
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	0.00	0.00	0.00	0.00	0.02	0.02
9	0.00	0.02	0.02	0.02	0.02	0.02	0.02
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.02	0.02	0.00	0.00	0.00	0.00	0.02
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.02	0.02	0.02	0.02	0.02	0.01	0.02
19	0.02	0.00	0.00	0.00	0.00	0.02	0.02
20	0.00	0.00	0.00	0.02	0.02	0.01	0.02
21	0.01	0.02	0.02	0.00	0.00	0.01	0.02
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.00	0.02	0.02	0.02	0.02	0.02
24	0.01	0.01	0.02	0.02	0.00	0.01	0.02
25	0.01	0.02	0.02	0.02	0.00	0.00	0.02
26	0.00	0.00	0.00	0.00	0.00	0.00	0.00
27	0.00	0.00	0.00	0.00	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.00	0.01	0.02
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.02	0.02	0.02	0.02	0.00	0.00	0.02
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1.0 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: 0.00= Plant Offline		PRINTED NAME: Jonathan Woody	
		SIGNATURE: <i>Jonathan Woody</i>	DATE: 9-5-23
		PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: USFS Wolf Creek Job Corps	ID#: 41	01095	Month/Year: Aug-23	Disinfection <i>Giardia</i> Log Inactiv: 0.5
--	---------	-------	--------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1-		93						44
2-0750	0.9	93	83.7	21.0	7.40	10.4	yes	44
3-		93						44
4-0810	0.9	93	83.7	21.0	7.70	11.7	yes	44
5-		93						44
6-1530	0.7	93	65.1	23.0	7.90	10.8	yes	44
7-0750	0.9	93	83.7	22.0	7.80	11.3	yes	44
8-0800	1.1	93	102.3	21.0	7.20	9.9	yes	44
9-0750	0.7	93	65.1	22.0	7.10	8.5	yes	44
10-		93						44
11-0730	0.7	93	65.1	21.0	7.20	9.5	yes	44
12-		93						44
13-0830	0.5	93	46.5	22.0	7.50	9.7	yes	44
14-		93						44
15-		93						44
16-1030	0.9	93	83.7	23.0	7.10	8.1	yes	44
17-		93						44
18-1351	0.5	93	46.5	24.0	7.10	7.3	yes	44
19-0755	1.1	93	102.3	21.0	7.30	10.3	yes	44
20-0820	0.6	93	55.8	23.0	7.10	7.9	yes	44
21-0810	1.1	93	102.3	20.0	7.20	10.6	yes	44
22-		93						44
23-0800	0.5	93	46.5	22.0	8.00	11.7	yes	44
24-0800	1	93	93.0	19.0	7.20	11.2	yes	44
25-1130	0.6	93	55.8	23.0	8.00	11.0	yes	44
26-		93						44
27-1445	0.4	93	37.2	24.0	8.10	10.5	yes	44
28-0800	0.9	93	83.7	20.0	7.00	9.6	yes	44
29-		93						44
30-0800	0.5	93	46.5	22.0	7.90	11.2	yes	44
31-0800	0.9	93	83.7	21.0	7.70	11.7	yes	44

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.