

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Polk

Month/Year:

Jun-22

System Name:		Buell Red Prairie Water District ID #41-01174					WTP : TP -	
Day		24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1		0.05	0.05	0.05	0.05	0.05	0.05	0.05
2		0.05	0.05	0.05	0.05	0.05	0.05	0.05
3		0.05	0.05	0.05	0.05	0.05	0.05	0.05
4		0.05	0.05	0.05	0.05	0.05	0.05	0.05
5		0.05	0.05	0.05	0.05	0.05	0.05	0.05
6		0.05	0.05	0.05	0.05	0.05	0.05	0.05
7		0.05	0.05	0.05	0.05	0.05	0.05	0.05
8		0.05	0.05	0.05	0.05	0.05	0.05	0.05
9		0.05	0.05	0.05	0.05	0.05	0.05	0.05
10		0.05	0.05	0.05	0.05	0.05	0.05	0.05
11		0.05	0.05	0.05	0.05	0.05	0.05	0.05
12		0.05	0.05	0.05	0.05	0.05	0.05	0.05
13		0.05	0.05	0.05	0.05	0.05	0.05	0.05
14		0.05	0.05	0.05	0.05	0.05	0.05	0.05
15		0.05	0.05	0.05	0.05	0.05	0.05	0.05
16		0.05	0.05	0.05	0.05	0.05	0.05	0.05
17		0.05	0.05	0.05	0.05	0.05	0.05	0.05
18		0.05	0.05	0.05	0.05	0.05	0.05	0.05
19		0.05	0.05	0.05	0.05	0.05	0.05	0.05
20		0.05	0.05	0.05	0.05	0.05	0.05	0.05
21		0.05	0.05	0.05	0.05	0.05	0.05	0.05
22		0.05	0.05	0.05	0.05	0.05	0.05	0.05
23		0.05	0.05	0.05	0.05	0.05	0.05	0.05
24		0.05	0.05	0.05	0.05	0.05	0.05	0.05
25		0.05	0.05	0.05	0.05	0.05	0.05	0.05
26		0.05	0.05	0.05	0.05	0.05	0.05	0.05
27		0.05	0.05	0.05	0.05	0.05	0.05	0.05
28		0.05	0.05	0.05	0.05	0.05	0.05	0.05
29		0.05	0.05	0.05	0.05	0.05	0.05	0.05
30		0.05	0.05	0.05	0.05	0.05	0.05	0.05
31								
								Monthly Summary (Answer Yes or No)
95% of 4-hour turbidity readings ≤ 0.3 NTU?				<input checked="" type="checkbox"/> yes	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?	
All 4-hour turbidity readings ≤ 1 NTU?				<input checked="" type="checkbox"/> Yes			<input checked="" type="checkbox"/> Yes	
All turbidity readings < IFE ² triggers								
Notes:				Printed Darrel Lockard				
				SIGNATURE <i>Darrel Lockard</i>			07/10/22	
				Phone# 541- 222-9997			CERT# 2853	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	Buell Red Prairie Water District	ID# 41-01174	Month/Year:	Jun-22	Disinfection Giardia Log Inactiv:	0.5
--------------	----------------------------------	--------------	-------------	--------	-----------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 0800	1.47	60	88.2	14.2	7.90	21.1	YES	110
2 / 0800	1.51	60	90.6	14.6	7.90	20.7	YES	110
3 / 0800	1.4	60	84.0	14.9	7.90	20.0	YES	110
4 / 0800	1.5	60	90.0	14.7	7.90	20.5	YES	110
5 / 0800	1.68	60	100.8	14.6	7.90	21.1	YES	110
6 / 0800	1.85	60	111.0	14.7	7.90	21.3	YES	110
7 / 0800	1.48	60	88.8	14.4	7.90	20.9	YES	110
8 / 0800	1.55	60	93.0	14.5	7.90	20.9	YES	110
9 / 0800	1.61	60	96.6	14.7	7.90	20.8	YES	110
10 / 0800	1.53	60	91.8	14.8	7.90	20.4	YES	110
11 / 0800	1.58	60	94.8	14.2	7.90	21.4	YES	110
12 / 0800	1.46	60	87.6	12.9	7.80	22.2	YES	110
13 / 0800	1.55	60	93.0	12.2	7.90	24.4	YES	110
14 / 0800	1.38	60	82.8	12.0	7.90	24.2	YES	110
15 / 0800	1.41	60	84.6	12.1	7.90	24.1	YES	110
16 / 0800	1.49	60	89.4	12.1	7.90	24.4	YES	110
17 / 0800	1.51	60	90.6	12.1	7.90	24.4	YES	110
18 / 0800	1.52	60	91.2	12.3	7.90	24.1	YES	110
19 / 0800	1.45	60	87.0	12.9	7.90	23.0	YES	110
20 / 0800	1.79	60	107.4	13.1	7.90	23.6	YES	110
21 / 0800	1.65	60	99.0	14.0	7.90	21.9	YES	110
22 / 0800	1.49	60	89.4	14.9	7.90	20.2	YES	110
23 / 0800	1.54	60	92.4	14.8	7.90	20.5	YES	110
24 / 0800	1.53	60	91.8	16.0	7.90	18.9	YES	110
25 / 0800	1.8	60	108.0	16.8	7.90	18.5	YES	110
26 / 0800	1.79	60	107.4	17.4	7.60	15.9	YES	110
27 / 0800	1.77	60	106.2	18.2	7.60	15.0	YES	110
28 / 0800	1.78	60	106.8	17.6	7.80	16.8	YES	110
29 / 0800	1.72	60	103.2	16.8	7.80	17.6	YES	110
30 / 0800	1.69	60	101.4	16.7	7.80	17.7	YES	110

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.