


### Oregon DHS - Drinking Water Program - Turbidity Monitoring Report Form

System Name: Young Life

ID# 4101246 WTP:-A

Month/Year: May 2022

DAY	12:00 AM	4:00 AM	8:00 AM	NOON	4:00 PM	8:00 PM	Highest Reading of the Day <sup>1</sup>	PLANT FLOW RATE
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	Flow [GPM]
1			0.045				0.045	80
2				0.045			0.045	80
3				0.045			0.045	80
4			0.056				0.056	80
5			0.044				0.044	80
6			0.043				0.043	80
7			0.044				0.044	80
8			0.043				0.043	80
9			0.044				0.044	80
10				0.044			0.044	80
11			0.044				0.044	80
12			0.044				0.044	80
13			0.044				0.044	80
14			0.045				0.045	80
15			0.044				0.044	80
16			0.044				0.044	80
17			0.044				0.044	80
18			0.044				0.044	80
19			0.044				0.044	80
20			0.044				0.044	80
21			0.045				0.045	80
22			0.043				0.043	80
23			0.044				0.044	80
24				0.043			0.043	80
25			0.044				0.044	80
26				0.044			0.044	80
27			0.044				0.044	80
28			0.043				0.043	80
29			0.044				0.044	80
30			0.043				0.043	80
31			0.044				0.044	80

<b>Conventional or Direct Filtration Monthly Summary</b>		<b>Monthly UV Summary (Circle Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? All the 4-hour turbidity readings < 1 NTU? All turbidity readings < IFE triggers?		Is the volume of off-spec water produced less than 5% in the month?	
- OR -		PRINTED NAME: William B. Palmayesa	
<b>Slow Sand/Cartridge/Membrane/DE Filtration</b>		SIGNATURE: 	DATE: 6/10/22
95% of turbidity readings ≤ 1 NTU? All turbidity readings < 5 NTU?		PHONE #: (541) 489-3100	CERT #: T8425 D8424
Is there 4-log virus inactivation provided with <input checked="" type="checkbox"/> Chlorine; <input type="checkbox"/> Other _____		CT Viral: Required <input checked="" type="checkbox"/> Achieved <input checked="" type="checkbox"/>	

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>IFE = Individual Filter Effluent. (OAR 333-061-0040(1)(d)(B&C))

OHA - Drinking Water Services - Surface Water Quality (CL) Data Form

County: WASCO

System Name: Young Life

ID# 4101246 WTP-: A

Month/Year: May 2022

Date/ Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]
01/0730	0.6	162	97.2	12.8	7.6	5.2	Yes	130
02/1230	0.6	162	97.2	12.9	7.6	5.2	Yes	102
03/1515	0.7	162	113.4	13.3	7.7	4.8	Yes	120
04/0815	0.6	162	97.2	13.3	7.6	4.8	Yes	122
05/0150	0.6	162	97.2	13.2	7.7	4.8	Yes	115
06/0700	0.6	162	97.2	13.3	7.7	4.8	Yes	112
07/0815	0.6	162	97.2	14.1	7.6	4.4	Yes	95
08/0800	0.6	162	97.2	13.9	7.6	4.8	Yes	119
09/0700	0.6	162	97.2	13.9	7.6	4.8	Yes	118
10/1030	0.6	162	97.2	13.8	7.7	4.8	Yes	94
11/0845	0.6	162	97.2	13.8	7.6	4.8	Yes	92
12/1025	0.6	162	97.2	13.9	7.6	4.8	Yes	114
13/0850	0.6	162	97.2	14.0	7.6	4.4	Yes	114
14/0855	0.6	162	97.2	14.0	7.6	4.4	Yes	124
15/0825	0.6	162	97.2	14.1	7.6	4.4	Yes	100
16/0855	0.6	162	97.2	14.4	7.6	4.4	Yes	113
17/0740	0.6	162	97.2	14.7	7.6	4.4	Yes	113
18/1000	0.6	162	97.2	15.0	7.6	4.0	Yes	116
19/0930	0.6	162	97.2	15.1	7.6	4.0	Yes	118
20/1010	0.6	162	97.2	15.1	7.5	4.0	Yes	122
21/0800	0.6	162	97.2	15.1	7.5	4.0	Yes	117
22/0822	0.6	162	97.2	15.2	7.5	4.0	Yes	125
23/0840	0.6	162	97.2	15.3	7.5	4.0	Yes	159
24/0730	0.6	162	97.2	15.6	7.5	4.0	Yes	132
25/0735	0.5	162	81	15.9	7.5	4.0	Yes	153
26/1115	0.6	162	97.2	16.1	7.5	3.8	Yes	155
27/1030	0.6	162	97.2	16.4	7.5	3.8	Yes	126
28/0925	0.6	162	97.2	16.3	7.5	3.8	Yes	127
29/0820	0.6	162	97.2	16.2	7.5	3.8	Yes	126
30/0900	0.7	162	113.4	16.0	7.5	3.8	Yes	178
31/1025	0.8	162	129.6	15.8	7.5	4.0	Yes	132

If CL2 at entry point < 0.2 mg/L OR CT not met, notify DWS within 24 hours

**Oregon DHS - Drinking Water Program - Surface Water (UVT) Quality Data**

**County: WASCO**

**System Name: Young Life**

**PWS ID # 4101246**

**Month/Year: May 2022**

Minimum UVT [%] during month: 93.1 Duty sensor variation from reference sensor: 1 Minimum Validated UVT: 79.9%

Date	Peak Hourly Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Cumulative Water Produced	Water outside Validated Conditions {B}	Cumulative Water outside Val. Cond.	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[ $mW/cm^2$ ]	[ Y or N ]	[gal]		[gal]		(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100[%]
1	81	39.0	Yes	79,870	79,870	0	0	0.0000%
2	75	40.5	Yes	78,870	158,740	0	0	0.0000%
3	74	37.5	Yes	83,880	242,620	0	0	0.0000%
4	78	37.5	Yes	93,490	336,110	0	0	0.0000%
5	81	40.5	Yes	69,360	405,470	0	0	0.0000%
6	79	39.0	Yes	60,490	465,960	0	0	0.0000%
7	81	40.5	Yes	60,690	526,650	0	0	0.0000%
8	79	40.5	Yes	83,000	609,650	0	0	0.0000%
9	86	40.5	Yes	73,640	683,290	0	0	0.0000%
10	84	40.5	Yes	59,380	742,670	0	0	0.0000%
11	82	40.5	Yes	60,860	803,530	0	0	0.0000%
12	84	42.0	Yes	84,990	888,520	0	0	0.0000%
13	92	45.0	Yes	70,780	959,300	0	0	0.0000%
14	86	40.5	Yes	61,130	1,020,430	0	0	0.0000%
15	78	40.5	Yes	61,360	1,081,790	0	0	0.0000%
16	80	42.0	Yes	71,270	1,153,060	0	0	0.0000%
17	78	42.0	Yes	61,990	1,215,050	0	0	0.0000%
18	78	40.5	Yes	60,350	1,275,400	0	0	0.0000%
19	89	40.5	Yes	79,340	1,354,740	0	0	0.0000%
20	83	49.5	Yes	85,960	1,440,700	0	0	0.0000%
21	82	90.4	Yes	74,570	1,515,270	0	0	0.0000%
22	85	93.4	Yes	80,430	1,595,700	0	0	0.0000%
23	83	93.4	Yes	84,770	1,680,470	0	0	0.0000%
24	81	93.4	Yes	64,740	1,745,210	0	0	0.0000%
25	79	87.4	Yes	81,400	1,826,610	0	0	0.0000%
26	82	94.9	Yes	79,660	1,906,270	0	0	0.0000%
27	80	87.4	Yes	81,390	1,987,660	0	0	0.0000%
28	79	93.4	Yes	75,800	2,063,460	0	0	0.0000%
29	80	88.8	Yes	104,300	2,167,760	0	0	0.0000%
30	81	88.9	Yes	108,120	2,275,880	0	0	0.0000%
31	84	84.3	Yes	88,300	2,364,180	0	0	0.0000%
<b>Monthly Cumulative % Off-Spec Water Produced</b>								<b>0.0000%</b>

Signature 

Op. Cert.#: T8425 D8424

Date: 6/10/22