

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Curry

Conventional or Direct Filtration

Month/Year: Feb - 22

System Name:	Rainbow Rock Service Association		ID#: 41	01361		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.03	0.03	0.03	Pol	Pol	Pol	0.03
2							OFF
3							↓
4							↓
5							↓
6							↓
7							↓
8	Pol	Pol	Pol	0.05	0.04	0.04	0.05
9	0.04	0.04	Pol	Pol	Pol	Pol	0.04
10	Pol	Pol	Pol	0.04	0.04	Pol	0.04
11							OFF
12							↓
13							↓
14							↓
15	Pol	Pol	Pol	0.04	Pol	Pol	0.04
16	Pol	Pol	0.04	0.03	0.03	Pol	0.04
17	Pol	Pol	Pol	0.04	0.04	Pol	0.04
18							OFF
19							↓
20							↓
21							↓
22	Pol	Pol	Pol	0.05	0.04	0.04	0.05
23	0.04	0.04	0.04	Pol	Pol	Pol	0.04
24							OFF
25							↓
26							↓
27							↓
28							↓
29							
30							
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No
 All 4-hour turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back)

All Cl₂ residual at entry point ≥ 0.2 mg/l?

Yes / No

Yes / No

Notes:

PRINTED NAME: Jonathan Woody

SIGNATURE: *Jonathan Woody*

DATE: 3-9-2022

PHONE #: (541) 643-6137

CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Rainbow Rock Service Association

ID#: 41

01361

Month/Year: Feb - 22

Disinfection Giardia
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1.38	71	98	9.2	7.68	76	Yes	20
2		↑					OFF	↑
3								
4								
5								
6								
7								
8	1.25		89	10.9	7.0	39	Yes	
9	1.18		84	11.6	6.74	41	Yes	
10	.73		52	16.6	6.29	20	Yes	
11								
12								
13								
14								
15	.86		61	11.5	6.90	37	Yes	
16	1.03		73	12	8.08	67	Yes	
17	1.01		72	10.5	7.20	46	Yes	
18							OFF	
19								
20								
21								
22	1.08		77	10.7	7.51	55	Yes	
23	1.36		97	8.8	7.05	62	Yes	
24							OFF	
25								
26								
27								
28								
29								
30								
31		↓						↓

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.