

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **CURRY**
 Month/Year: **Apr-22**

System Name:	Rainbow Rock Service Association		ID#: 41	01361		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	POL	POL	POL	POL	POL	POL	
2	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	0.04	0.04	POL	0.04
7	POL	POL	POL	0.04	0.04	POL	0.04
8	POL	POL	POL	POL	POL	POL	
9	POL	POL	POL	POL	POL	POL	
10	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	POL	0.05	0.04	0.05
12	0.04	0.04	0.05	POL	POL	POL	0.05
13	POL	POL	POL	POL	POL	POL	
14	POL	POL	POL	POL	POL	POL	
15	POL	POL	POL	POL	POL	POL	
16	POL	POL	POL	POL	POL	POL	
17	POL	POL	POL	POL	POL	POL	
18	POL	POL	POL	0.05	POL	POL	0.05
19	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	0.05	0.04	POL	0.05
21	POL	POL	POL	POL	POL	POL	
22	POL	POL	POL	POL	POL	POL	
23	POL	POL	POL	POL	POL	POL	
24	POL	POL	POL	POL	POL	POL	
25	POL	POL	0.05	0.05	0.05	0.04	0.05
26	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	0.03	POL	POL	0.03
28	POL	POL	0.04	0.03	POL	POL	0.04
29	POL	POL	POL	POL	POL	POL	
30	POL	POL	POL	POL	POL	POL	
31	POL	POL	POL	POL	POL	POL	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Jonathan Woody	
	SIGNATURE: <i>Jonathan Woody</i>	DATE: 5/9/22
	PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Rainbow Rock Service Association ID#: 41 01361 Month/Year: Apr-22 Disinfection *Giardia* Log Inactiv: 1


Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	71	#VALUE!			#VALUE!		20
2	POL	71	#VALUE!			#VALUE!		20
3	POL	71	#VALUE!			#VALUE!		20
4	POL	71	#VALUE!			#VALUE!		20
5	POL	71	#VALUE!			#VALUE!		20
6	1.05	71	74.6	15.9	6.60	22.2	YES	20
7	0.76	71	54.0	14.7	7.02	27.2	YES	20
8	POL	71	#VALUE!			#VALUE!		20
9	POL	71	#VALUE!			#VALUE!		20
10	POL	71	#VALUE!			#VALUE!		20
11	1.85	71	131.4	12.4	7.56	44.1	YES	20
12	1.38	71	98.0	10.8	7.04	38.8	YES	20
13	POL	71	#VALUE!			#VALUE!		20
14	POL	71	#VALUE!			#VALUE!		20
15	POL	71	#VALUE!			#VALUE!		20
16	POL	71	#VALUE!			#VALUE!		20
17	POL	71	#VALUE!			#VALUE!		20
18	1.18	71	83.8	15.1	6.73	25.0	YES	20
19	POL	71	#VALUE!			#VALUE!		20
20	1.47	71	104.4	13.9	6.64	27.1	YES	20
21	POL	71	#VALUE!			#VALUE!		20
22	POL	71	#VALUE!			#VALUE!		20
23	POL	71	#VALUE!			#VALUE!		20
24	POL	71	#VALUE!			#VALUE!		20
25	1.68	71	119.3	16.0	6.76	25.2	YES	20
26	POL	71	#VALUE!			#VALUE!		20
27	1.62	71	115.0	12.8	6.37	26.8	YES	20
28	0.82	71	58.2	16.0	6.81	23.2	YES	20
29	POL	71	#VALUE!			#VALUE!		20
30	POL	71	#VALUE!			#VALUE!		20
31	POL	71	#VALUE!			#VALUE!		20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Rainbow Rock Service Association ID# 41 01361 Month/Year: Apr / 2022
 Minimum UVT [%] during month: 85 Duty sensor variation from reference sensor %: 0%
 Minimum Validated UVT: 75%

Date	Peak Hourly Demand Flow [gpm/unit]	Minimum Intensity [^{mW} /cm ²]	All Lamps On? [Y or N]	Daily Water Produced {A} [gal]	Water outside Validated Conditions {B} [gal]	Cumulative % Off-Spec Water Produced (Mo. Sum {B}) + (Mo. Sum {A}) * 100 [%]
1	POL					
2	POL					
3	POL					
4	POL					
5	POL					
6	20	51.2	Y	6984	0	
7	20	51.4	Y	6432	0	
8	POL					
9	POL					
10	POL					
11	20	51.7	Y	14810	0	
12	20	49.1	Y	10771	0	
13	POL					
14	POL					
15	POL					
16	POL					
17	POL					
18	20	51.3	Y	4189	0	
19	POL					
20	20	51.2	Y	11594	0	
21	POL					
22	POL					
23	POL					
24	POL					
25	20	52.2	Y	16530	0	
26	POL					
27	20	52.7	Y	7405	0	
28	20	50.9	Y	8302	0	
29	POL					
30	POL					
31						
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: 7232

Date: 5/9/2022