

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **CURRY**
 Month/Year: **Jun-22**

System Name:	Rainbow Rock Service Association			ID#: 41	01361		WTP : TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	POL	POL	POL	0.01	0.01	POL	0.01	
2	POL	POL	POL	POL	POL	POL	POL	
3	POL	POL	POL	POL	POL	POL	POL	
4	POL	POL	POL	POL	POL	POL	POL	
5	POL	POL	POL	POL	POL	POL	POL	
6	POL	POL	POL	0.01	0.01	POL	0.01	
7	POL	POL	POL	POL	POL	POL	POL	
8	POL	POL	POL	POL	POL	POL	POL	
9	POL	POL	0.01	0.01	0.01	0.01	0.01	
10	POL	POL	POL	POL	POL	POL	POL	
11	POL	POL	POL	POL	POL	POL	POL	
12	POL	POL	POL	POL	POL	POL	POL	
13	POL	POL	0.01	0.01	0.01	POL	0.01	
14	POL	POL	POL	0.01	0.01	POL	0.01	
15	POL	POL	POL	POL	POL	POL	POL	
16	POL	POL	POL	0.01	0.01	0.01	0.01	
17	POL	POL	POL	POL	POL	POL	POL	
18	POL	POL	POL	POL	POL	POL	POL	
19	POL	POL	POL	POL	POL	POL	POL	
20	POL	POL	POL	POL	POL	POL	POL	
21	POL	POL	POL	POL	POL	POL	POL	
22	POL	POL	0.01	0.05	0.04	0.04	0.05	
23	0.04	0.04	POL	0.04	POL	POL	0.04	
24	POL	POL	POL	POL	POL	POL	POL	
25	POL	POL	POL	POL	POL	POL	POL	
26	POL	POL	POL	POL	POL	POL	POL	
27	POL	POL	POL	POL	POL	POL	POL	
28	POL	POL	POL	POL	POL	POL	POL	
29	POL	POL	POL	POL	POL	POL	POL	
30	POL	POL	POL	POL	POL	POL	POL	
31								

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes: POL= Plant Offline			PRINTED NAME: Jonathan Woody	
			SIGNATURE: <i>Jonathan Woody</i>	DATE: 7/10/2022
			PHONE #: (541) 643-6137	CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Rainbow Rock Service Association ID#: 41 01361 Month/Year: Jun-22 Disinfection *Giardia* Log Inactiv: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1.3	71	92.3	14.2	6.16	21.7	YES	20
2		71					POL	20
3		71					POL	20
4		71					POL	20
5		71					POL	20
6	2.13	71	151.2	15.5	6.74	27.2	YES	20
7		71					POL	20
8		71					POL	20
9	1.93	71	137.0	15.2	7.66	38.1	YES	20
10		71					POL	20
11		71					POL	20
12		71					POL	20
13	1.71	71	121.4	14.5	6.44	24.8	YES	20
14	1.43	71	101.5	15.5	7.29	30.8	YES	20
15		71					POL	20
16	1.72	71	122.1	14.5	6.55	25.9	YES	20
17		71					POL	20
18		71					POL	20
19		71					POL	20
20		71					POL	20
21		71					POL	20
22	1.96	71	139.2	18.0	6.35	19.5	YES	20
23	1.81	71	128.5	14.4	6.37	24.6	YES	20
24		71					POL	20
25		71					POL	20
26		71					POL	20
27		71					POL	20
28		71					POL	20
29		71					POL	20
30		71					POL	20
31		71					POL	20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

WTP A Camp Curry

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Rainbow Rock Service Association ID# 41 01361 Month/Year: Jun / 2022
 Minimum UVT [%] during month: 88 Duty sensor variation from reference sensor %: 0%
 Minimum Validated UVT: 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	20	51.5	Y	8378	0	
2	POL					
3	POL					
4	POL					
5	POL					
6	20	50.4	Y	10173	0	
7	POL					
8	POL					
9	20	51.2	Y	15484	0	
10	POL					
11	POL					
12	POL					
13	20	50	Y	11669	0	
14	20	50.7	Y	10996	0	
15	POL					
16	20	50.5	Y	18256	0	
17	POL					
18	POL					
19	POL					
20	POL					
21	POL					
22	20	50.5	Y	19100	0	
23	20	50.1	Y	10737	0	
24	POL					
25	POL					
26	POL					
27	POL					
28	POL					
29	POL					
30	POL					
31						
Monthly Cumulative % Off-Spec Water Produced						0

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

POL= Plant offline

Signature: *John W...*

Op Cert #: 7232

Date: 7/10/2022