

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **CURRY**
 Month/Year: **Jun-24**

System Name:	Rainbow Rock Service Association			ID#: 41	01361		WTP: TP -	A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	POL	POL	POL	POL	POL	POL		
2	POL	POL	POL	POL	POL	POL		
3	POL	POL	POL	POL	POL	POL		
4	POL	POL	POL	POL	POL	POL		
5	POL	POL	POL	POL	0.08	0.05		0.05
6	0.04	0.04	0.04	0.04	POL	POL		0.04
7	POL	POL	POL	POL	POL	POL		
8	POL	POL	POL	POL	POL	POL		
9	POL	POL	POL	POL	POL	POL		
10	POL	POL	POL	POL	POL	POL		
11	POL	POL	POL	POL	POL	POL		
12	POL	POL	POL	POL	POL	POL		
13	POL	POL	0.10	0.07	0.06	0.05		0.10
14	0.05	0.05	POL	POL	POL	POL		0.05
15	POL	POL	POL	POL	POL	POL		
16	POL	POL	POL	POL	POL	POL		
17	POL	POL	POL	POL	POL	POL		
18	POL	POL	POL	POL	0.07	0.07		0.07
19	0.07	0.06	0.06	0.05	POL	POL		0.07
20	POL	POL	POL	POL	POL	POL		
21	POL	POL	POL	POL	POL	POL		
22	POL	POL	POL	POL	POL	POL		
23	POL	POL	POL	POL	POL	POL		
24	POL	POL	POL	POL	0.07	0.07		0.07
25	0.07	0.06	0.06	0.06	POL	POL		0.07
26	POL	POL	POL	POL	POL	POL		
27	POL	POL	POL	POL	POL	POL		
28	POL	POL	POL	POL	POL	POL		
29	POL	POL	POL	POL	POL	POL		
30	POL	POL	POL	POL	POL	POL		
31	POL	POL	POL	POL	POL	POL		

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		

Notes:	PRINTED NAME: Jonathan Woody
	SIGNATURE: <i>Jonathan Woody</i> DATE: 7-7-24
	PHONE #: (541) 643-6137 CERT #: 7232

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	Rainbow Rock Service Association	ID#: 41	01361	Month/Year:	Jun-24	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	----------------------------------	---------	-------	-------------	--------	--	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	POL	71	POL	POL	POL	POL	POL	20
2	POL	71	POL	POL	POL	POL	POL	20
3	POL	71	POL	POL	POL	POL	POL	20
4	POL	71	POL	POL	POL	POL	POL	20
5	1.02	71	72.4	15.0	7.35	31.1	YES	20
6	1.27	71	90.2	14.8	7.27	31.5	YES	20
7	POL	71	POL	POL	POL	POL	POL	20
8	POL	71	POL	POL	POL	POL	POL	20
9	POL	71	POL	POL	POL	POL	POL	20
10	POL	71	POL	POL	POL	POL	POL	20
11	POL	71	POL	POL	POL	POL	POL	20
12	POL	71	POL	POL	POL	POL	POL	20
13	1.09	71	77.4	13.2	7.10	32.2	YES	20
14	1.13	71	80.2	12.5	7.04	33.2	YES	20
15	POL	71	POL	POL	POL	POL	POL	20
16	POL	71	POL	POL	POL	POL	POL	20
17	POL	71	POL	POL	POL	POL	POL	20
18	0.84	71	59.6	14.7	7.12	28.5	YES	20
19	1.1	71	78.1	13.5	7.20	32.8	YES	20
20	POL	71	POL	POL	POL	POL	POL	20
21	POL	71	POL	POL	POL	POL	POL	20
22	POL	71	POL	POL	POL	POL	POL	20
23	POL	71	POL	POL	POL	POL	POL	20
24	1.08	71	76.7	14.4	7.22	31.0	YES	20
25	1.06	71	75.3	13.9	7.20	31.8	YES	20
26	POL	71	POL	POL	POL	POL	POL	20
27	POL	71	POL	POL	POL	POL	POL	20
28	POL	71	POL	POL	POL	POL	POL	20
29	POL	71	POL	POL	POL	POL	POL	20
30	POL	71	POL	OL	POL	POL	POL	20
31	POL	71	POL	POL	POL	POL	POL	20

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Rainbow Rock Service Association

ID# 41 01361

Month/Year: Jun / 2024

Minimum UVT [%] during month: 88

Duty sensor variation from reference sensor %: 0%

Minimum Validated UVT : 75%

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	POL	POL	POL	POL	0	
2	POL	POL	POL	POL	0	
3	POL	POL	POL	POL	0	
4	POL	POL	POL	POL	0	
5	26	57.4	Y	8,576	0	
6	26	57.2	Y	18,224	0	
7	POL	POL	POL	POL	0	
8	POL	POL	POL	POL	0	
9	POL	POL	POL	POL	0	
10	POL	POL	POL	POL	0	
11	POL	POL	POL	POL	0	
12	POL	POL	POL	POL	0	
13	26	56	Y	21,478	0	
14	26	53.2	Y	7,546	0	
15	POL	POL	POL	POL	0	
16	POL	POL	POL	POL	0	
17	POL	POL	POL	POL	0	
18	26	58	Y	10,215	0	
19	26	57.4	Y	17,025	0	
20	POL	POL	POL	POL	0	
21	POL	POL	POL	POL	0	
22	POL	POL	POL	POL	0	
23	POL	POL	POL	POL	0	
24	26	57.2	Y	10,209	0	
25	26	56.8	Y	18,615	0	
26	POL	POL	POL	POL	0	
27	POL	POL	POL	POL	0	
28	POL	POL	POL	POL	0	
29	POL	POL	POL	POL	0	
30	POL	POL	POL	POL	0	
31	POL	POL	POL	POL	0	
Monthly Cumulative % Off-Spec Water Produced						0

Signature: 

Op Cert #: 7232

Date: 7-7-24